



**2011 Annual Data Report
Nuiqsut Ambient Air Quality and Meteorological Monitoring
Program**

January 1, 2011 – December 31, 2011

**ConocoPhillips Alaska, Inc.
Nuiqsut, Alaska**

February 2012



AKreports@SLRconsulting.com
(907) 563-2137

2011 Annual Data Report


Prepared for:

ConocoPhillips Alaska, Inc.
700 G. St.
Anchorage, AK 99501

This document has been prepared by SLR International Corp. The material and data in this report were prepared under the supervision and direction of the undersigned.



K. Steven Mackey
SLR Project Manager



Gregg Malinky
SLR Project QA Officer

CONTENTS

| | |
|--|------------|
| EXECUTIVE SUMMARY | 1 |
| 1. INTRODUCTION..... | 1-1 |
| 1.1 Project Summary..... | 1-1 |
| 1.2 Measurement Methods Table..... | 1-6 |
| 1.2.1 Continuous NO ₂ , O ₃ , CO and SO ₂ Monitoring | 1-6 |
| 1.2.2 Continuous PM ₁₀ and PM _{2.5} Monitoring..... | 1-6 |
| 1.2.3 Meteorological Monitoring..... | 1-7 |
| 1.3 Variations from the QAPP | 1-9 |
| 2. STATION PERFORMANCE SUMMARY..... | 2-1 |
| 2.1 Significant Project Events..... | 2-1 |
| 2.2 Missing, Invalid and Adjusted Data | 2-3 |
| 2.3 Network Data Completeness..... | 2-5 |
| 2.4 Precision Statistics | 2-8 |
| 2.4.1 Monitoring Network Precision Statistics..... | 2-8 |
| 2.4.2 Analytical Laboratory Precision Statistics | 2-26 |
| 2.4.3 Analytical Laboratory Precision Statistics for Lead Analysis of Particulate Samples | 2-26 |
| 2.5 Accuracy Statistics | 2-26 |
| 2.5.1 Instrument Calibration Statistics | 2-26 |
| 2.5.2 Independent Quality Assurance Audits..... | 2-40 |
| 3. MONITORING DATA NETWORK SUMMARY..... | 3-1 |
| 3.1 Air Quality Data Summary..... | 3-1 |
| 3.2 Meteorological Data Summary | 3-14 |
| 3.2.1 Wind Speed (WS) and Wind Direction (WD) Climatology | 3-14 |
| 3.2.2 Temperature Climatology | 3-21 |
| 3.2.3 Other Meteorological Parameters..... | 3-26 |
| 4. REFERENCES..... | 4-1 |

TABLES

| | |
|---|-----|
| Table E-1: QAPP Variation Table | 1 |
| Table E-2: Nuiqsut Ambient Air Monitoring Summary Data | 2 |
| Table E-3: Meteorological Data Capture – Valid Hours per Month..... | 5 |
| Table E-4: Meteorological Data Capture – Percent Data Capture | 6 |
| Table 1-1: Gaseous Pollutant Measurement Parameters | 1-6 |
| Table 1-2: PM Monitoring Measurement Parameters | 1-7 |
| Table 1-3: Meteorological Measurement Methods..... | 1-8 |
| Table 1-4: QAPP Variation Table..... | 1-9 |
| Table 2-1: Chronology of Significant Events | 2-1 |
| Table 2-2: Percentage of Final Data Set Flagged..... | 2-4 |
| Table 2-3: Ambient Air Quality Data Capture Percent | 6 |
| Table 2-4: Meteorological Data Capture Percent..... | 7 |

CONTENTS (continued)

| | |
|---|------|
| Table 2-5: 1 st Quarter O ₃ Precision Statistics Summary..... | 2-9 |
| Table 2-6: 2 nd Quarter O ₃ Precision Statistics Summary..... | 2-10 |
| Table 2-7: 3 rd Quarter O ₃ Precision Statistics Summary..... | 2-11 |
| Table 2-8: 4 th Quarter O ₃ Precision Statistics Summary..... | 2-12 |
| Table 2-9: 1 st Quarter SO ₂ Precision Statistics Summary..... | 2-13 |
| Table 2-10: 2 nd Quarter SO ₂ Precision Statistics Summary..... | 2-14 |
| Table 2-11: 3 rd Quarter SO ₂ Precision Statistics Summary..... | 2-15 |
| Table 2-12: 4 th Quarter SO ₂ Precision Statistics Summary..... | 2-16 |
| Table 2-13: 1 st Quarter NO ₂ Precision Statistics Summary..... | 2-17 |
| Table 2-14: 2 nd Quarter NO ₂ Precision Statistics Summary..... | 2-18 |
| Table 2-15: 3 rd Quarter NO ₂ Precision Statistics Summary..... | 2-19 |
| Table 2-16: 4 th Quarter NO ₂ Precision Statistics Summary..... | 2-20 |
| Table 2-17: 1 st Quarter CO Precision Statistics Summary..... | 2-21 |
| Table 2-18: 2 nd Quarter CO Precision Statistics Summary..... | 2-22 |
| Table 2-19: 3 rd Quarter CO Precision Statistics Summary..... | 2-23 |
| Table 2-20: 4 th Quarter CO Precision Statistics Summary..... | 2-24 |
| Table 2-21: Quarterly Network PM _{2.5} Monitoring Precision Statistics..... | 2-25 |
| Table 2-22: Quality Control Checks PM _{2.5} | 2-27 |
| Table 2-23: Quality Control Checks PM ₁₀ | 2-28 |
| Table 2-24: Calibration Summary – SO ₂ | 2-29 |
| Table 2-25: Calibration Summary – CO..... | 2-31 |
| Table 2-26: Calibration Summary – O ₃ | 2-33 |
| Table 2-27: Calibration Summary – NO ₂ | 2-35 |
| Table 2-28: March 5, 2011 Meteorological Calibration Summary..... | 2-37 |
| Table 2-29: May 29, 2011 Meteorological Calibration Summary..... | 2-38 |
| Table 2-30: November 7, 2011 Meteorological Calibration Summary..... | 2-39 |
| Table 2-31: Performance Audit Summary – SO ₂ | 2-41 |
| Table 2-32: Performance Audit Summary – CO..... | 2-42 |
| Table 2-33: Performance Audit Summary – O ₃ | 2-43 |
| Table 2-34: Performance Audit Summary – NO ₂ | 2-44 |
| Table 2-35: Performance Audit Summary – PM _{2.5} | 2-45 |
| Table 2-36: Performance Audit Summary – PM ₁₀ | 2-45 |
| Table 2-37: June 2, 2011 Meteorological Performance Audit Summary..... | 2-46 |
| Table 2-38: November 7, 2011 Meteorological Performance Audit Summary..... | 2-47 |
| Table 2-39: Wainwright PM _{2.5} PEP Audit Results..... | 2-48 |
| Table 3-1: Nuiqsut Ambient Air Monitoring Summary Data..... | 3-2 |
| Table 3-2: Average and Maximum Wind Speeds at Kuparuk..... | 3-14 |
| Table 3-3: Average and Maximum Wind Speeds at Nuiqsut Station..... | 3-15 |
| Table 3-4: Annual Wind Rose Frequency Distribution Percentage..... | 3-17 |
| Table 3-5: First Quarter Wind Rose Frequency Distribution Percentage..... | 3-17 |
| Table 3-6: Second Quarter Wind Rose Frequency Distribution Percentage..... | 3-18 |
| Table 3-7: Third Quarter Wind Rose Frequency Distribution Percentage..... | 3-18 |
| Table 3-8: Fourth Quarter Wind Rose Frequency Distribution Percentage..... | 3-19 |
| Table 3-9: 2-Meter Temperature Summary..... | 3-22 |
| Table 3-10: 10-Meter Temperature Summary..... | 3-23 |
| Table 3-11: Solar Radiation Summary..... | 3-26 |

FIGURES

| | |
|---|-----|
| Figure 1-1: Local Map of Nuiqsut..... | 1-3 |
| Figure 1-2: Aerial Photo Showing Site Location..... | 1-4 |

CONTENTS (continued)

| | |
|--|------|
| Figure 1-3: Area Map | 1-5 |
| Figure 3-1: 8-Hour Average O ₃ and NAAQS/AAAQS Standard..... | 3-5 |
| Figure 3-2: 1-Hour Average SO ₂ and NAAQS/AAAQS Standard | 3-6 |
| Figure 3-3: 3-Hour Average SO ₂ and NAAQS/AAAQS Standard | 3-7 |
| Figure 3-4: 24-Hour Average SO ₂ and NAAQS/AAAQS Standard | 3-8 |
| Figure 3-5: 1-Hour Average CO and NAAQS/AAAQS Standard | 3-9 |
| Figure 3-6: 8-Hour Average CO and NAAQS/AAAQS Standard | 3-10 |
| Figure 3-7: 1-Hour Average NO ₂ and NAAQS Standard ¹ | 3-11 |
| Figure 3-8: 24-Hour Average PM _{2.5} and NAAQS/AAAQS Standard | 3-12 |
| Figure 3-9: 24-Hour Average PM ₁₀ and NAAQS/AAAQS Standard..... | 3-13 |
| Figure 3-10: Nuiqsut Annual Wind Rose..... | 3-15 |
| Figure 3-11: Nuiqsut Quarterly Wind Roses | 3-16 |
| Figure 3-12: Annual Wind Rose Superimposed on Site Map | 3-20 |
| Figure 3-13: Hourly Average 2-Meter and 10-Meter Temperatures..... | 3-24 |
| Figure 3-14: Hourly Average Vertical Temperature Difference ¹ | 3-25 |
| Figure 3-15: Hourly Average Solar Radiation | 3-27 |

APPENDICES

| | |
|------------|--|
| Appendix A | Data Processing Specifications and Statistical Formulae |
| Appendix B | Precision Data |
| Appendix C | Accuracy Data |
| Appendix D | Validated Continuous Hourly/Daily/Monthly Data Summaries |
| Appendix E | Validated Manual Particulate (Field and Laboratory) Data |

EXECUTIVE SUMMARY

On behalf of ConocoPhillips Alaska, Inc. (CPAI), SLR International Corp (SLR) is collecting ambient air and meteorological data in the village of Nuiqsut, Alaska. Since April 9, 1999 (prior to construction of the Alpine Central Processing Facility), CPAI has operated an ambient air quality and dispersion meteorology monitoring station in Nuiqsut, Alaska, which is located on the Alaskan North Slope. The Nuiqsut Ambient Air Quality and Meteorological Monitoring Program is comprised of one station located at the northern edge of Nuiqsut approximately 400 meters north-northwest of the community electrical generators. Currently, the Nuiqsut Monitoring Program is being conducted on a voluntary basis to document air quality in Nuiqsut. The data may also be used to support various ambient air quality impact analyses conducted for oil field development in the Colville Delta region.

On January 1, 2011 SLR International Corporation (SLR) assumed responsibility for the operation and management of the Nuiqsut monitoring station, which is one of three independent ambient air and meteorological monitoring programs operated by CPAI on the North Slope of Alaska. The Nuiqsut monitoring program is designed and operated in accordance with applicable EPA PSD regulations and guidance documents. This report provides details of ambient air and meteorological measurements collected from the 2011 monitoring quarter, spanning from January 1, 2011 to December 31, 2011, at the Nuiqsut monitoring station.

Table E-1 details Quality Assurance Project Plan (QAPP) variations documented for this project during the monitoring year. QAPP variations are explained in more detail in Section 1. The Nuiqsut QAPP Revision 2.0 was submitted to USEPA Region 10 in July, 2011. Table E-2 provides a summary of quarterly and annual measured data for the monitored pollutants and the respective ratios of measured pollutants to National Ambient Air Quality Standards and Alaska Ambient Air Quality Standards (NAAQS/AAQS). Table E-3 provides monthly and annual valid percent data capture for the Nuiqsut meteorological monitoring station. Data not meeting QAPP and PSD precision and accuracy criteria were invalidated and are discussed in Section 2.

Table E-1: QAPP Variation Table

| Item / Procedure | Summary of QAPP Variation | Reason for Variation |
|---|---|--|
| The Nuiqsut Ambient Air Quality and Meteorological Monitoring Station QAPP submitted by AECOM in August 2010 stated that PM ₁₀ sampling is conducted using a Rupprecht & Patashnick Model 1400ab TEOM. | On March 3, 2011, the PM ₁₀ TEOM sampler was replaced with a Met One Instruments, Inc. BAM-1020 Beta Attenuation Mass Monitor. | The TEOM PM ₁₀ sampler was 12 years old and near the end of its life expectancy. The BAM-1020 PM ₁₀ sampler was chosen as a replacement for ease of operation and consistency among other SLR monitoring stations. |
| In the Nuiqsut QAPP submitted by SLR to ADEC in July 2011, it is stated that meteorological parameters to be measured would include relative humidity and barometric pressure. | Meteorological data for relative humidity and barometric pressure were not collected during the 2011 monitoring year. | The Nuiqsut station was not configured with relative humidity and barometric pressure sensors during the 2011 monitoring year. These parameters are not required for dispersion modeling. |

Table E-2: Nuiqsut Ambient Air Monitoring Summary Data

| Pollutant | National and Alaska Ambient Air Quality Standards (NAAQS/AAAQS) | | Nuiqsut Ambient Air Monitoring – Pollutant Data | | | | | | |
|-------------------------------------|---|---------------------|---|-------------------------|-------------------------|-------------------------|-------------------------|--------|----------------------|
| | Concentration | Averaging Period | Averaging Period | 1 st Quarter | 2 nd Quarter | 3 rd Quarter | 4 th Quarter | Annual | YTD % of NAAQS/AAAQS |
| Carbon Monoxide (CO) | 35 ppm (40,000 µg/m ³) | 1-Hour ¹ | 1 st Highest, 1-Hour Average | 2 | 1 | 1 | 1 | 2 | 5.7% |
| | | | 2 nd Highest, 1-Hour Average | 1 | 1 | 1 | 1 | 1 | 2.9% |
| | 9 ppm (10,000 µg/m ³) | 8-Hour ¹ | 1 st Highest, 8-Hour Average | 1 | 1 | 1 | 1 | 1 | 11.1% |
| | | | 2 nd Highest, 8-Hour Average | 1 | 1 | 1 | 1 | 1 | 11.1% |
| Nitrogen Dioxide (NO ₂) | 100.0 ppb (190 µg/m ³) | 1-Hour ² | Daily Max 1-Hour Averages (98 th Percentile) | - | - | - | - | 20.9 | 20.9% |
| | | | 1 st Highest, 1-Hour Average | 27.0 | 13.4 | 13.8 | 46.5 | 46.5 | 46.5% |
| | | | 2 nd Highest, 1-Hour Average | 26.0 | 13.1 | 13.6 | 25.6 | 27.0 | 27.0% |
| | 53 ppb (100 µg/m ³) | Annual | Average of Period | 3 | 1 | 1 | 2 | 2 | 3.8% |
| Ozone (O ₃) | 0.075 ppm (150 µg/m ³) | 8-Hour ³ | 4 th Highest, 8-Hour Average | 0.050 | 0.052 | 0.031 | 0.038 | 0.052 | 69.3% |
| | | | 1 st Highest, 8-Hour Average | 0.051 | 0.053 | 0.032 | 0.038 | 0.053 | 70.7% |
| | | | 2 nd Highest, 8-Hour Average | 0.051 | 0.053 | 0.032 | 0.038 | 0.053 | 70.7% |

¹ Not to be exceeded more than once each year.

² To attain this standard, the 3-year average of the 98th percentile of the annual daily maximum 1-hour average must not exceed 100 ppb. This standard is only an NAAQS, not an AAAQS.

³ To attain this standard, the 3-year average of the annual fourth-highest daily maximum 8-hour average must not exceed 0.075 ppm.

Table E-2 (Continued): Nuiqsut Ambient Air Monitoring Summary Data

| Pollutant | National and Alaska Ambient Air Quality Standards (NAAQS/AAQS) | | Nuiqsut Ambient Air Monitoring – Pollutant Data | | | | | | |
|-----------------------------------|--|----------------------|---|-------------------------|-------------------------|-------------------------|-------------------------|-------------|---------------------|
| | Concentration | Averaging Period | Averaging Period | 1 st Quarter | 2 nd Quarter | 3 rd Quarter | 4 th Quarter | Annual | YTD % of NAAQS/AAQS |
| Sulfur Dioxide (SO ₂) | 75.0 ppb (196 µg/m ³) | 1-Hour ¹ | Daily Max 1-Hour Averages (99 th Percentile) | - | - | - | - | 4.7 | 6.3% |
| | | | 1 st Highest, 1-Hour Average | 6.0 | 40.9 | 12.7 | 4.5 | 40.9 | 54.5% |
| | | | 2 nd Highest, 1-Hour Average | 5.0 | 4.5 | 6.0 | 2.6 | 12.7 | 16.9% |
| | 500.0 ppb (1,300 µg/m ³) | 3-Hour ² | 1st Highest, 3-Hour Average | 3.7 | 13.3 | 4.2 | 4.2 | 13.3 | 2.7% |
| | | | 2nd Highest, 3-Hour Average | 3.3 | 1.2 | 2.7 | 2.7 | 4.2 | 0.8% |
| | 140.0 ppb (365 µg/m ³) | 24-Hour ² | 1st Highest, 24-Hour Average | 3.0 | 1.2 | 1.1 | 0.8 | 3.0 | 2.1% |
| | | | 2nd Highest, 24-Hour Average | 2.5 | 0.1 | 0.3 | 0.8 | 2.5 | 1.9% |
| | 30.0 ppb (80 µg/m ³) | Annual | Average of Period | 0.3 | -0.4 | 0.1 | 0.2 | 0.0 | 0.0% |

¹ To attain this standard, the 3-year average of the 99th percentile of the annual daily maximum 1-hour average must not exceed 75.0 ppb.

² Not to be exceeded more than once each year.

Table E-2 (Continued): Nuiqsut Ambient Air Monitoring Summary Data

| Pollutant | National and Alaska Ambient Air Quality Standards (NAAQS/AAAQS) | | Nuiqsut Ambient Air Monitoring – Pollutant Data | | | | | | |
|---|---|----------------------|---|-------------------------|-------------------------|-------------------------|-------------------------|-------------|-----------------------------|
| | Concentration | Averaging Period | Averaging Period | 1 st Quarter | 2 nd Quarter | 3 rd Quarter | 4 th Quarter | Annual | YTD % of NAAQS/AAAQS |
| Particulate Matter <2.5 microns (PM _{2.5}) | 35.0 µg/m ³ | 24-Hour ¹ | 98 th Percentile, 24-Hour Average | - | - | - | - | 6.3 | 18.0% |
| | | | 1 st Highest, 24-Hour Average | 6.0 | 6.4 | 4.9 | 14.4 | 14.4 | 41.1% |
| | | | 2 nd Highest, 24-Hour Average | 5.6 | 6.3 | 4.6 | 10.1 | 10.1 | 28.9% |
| | 15.0 µg/m ³ | Annual ² | Average of Period | 1.9 | 1.9 | 0.4 | 1.4 | 1.4 | 9.3% |
| Particulate Matter <10 microns ¹ (PM ₁₀) | 150 µg/m ³ | 24-Hour ³ | 1 st Highest, 24-Hour Average | 10 | 220 ⁽⁴⁾ | 120 | 10 | 220 | 146.7%⁽⁴⁾ |
| | | | 2 nd Highest, 24-Hour Average | 10 | 40 | 40 | 10 | 120 | 80.0% |

¹ To attain this standard, the 3-year average of the 98th percentile of the 24-hour concentration must not exceed 35.0 µg/m³.

² To attain this standard, the 3-year average of the weighted annual mean PM_{2.5} concentration must not exceed 15.0 µg/m³.

³ Not to be exceeded more than once per year on average over three years.

⁴ The 1st highest reading of 220 µg/m³ is not an exceedance according to this standard. High PM₁₀ concentrations were measured on June 28, 2011 during a period of high winds from the east northeast direction. The average wind speeds were 10-12 m/s with wind directions between 53-77 degrees (clockwise from north) during the period of high PM₁₀ concentrations. These ENE winds were likely to have transported dust from the Colville River delta, since there was no snow cover at this time. Conditions were also quite dry at the time, as the nearby Deadhorse airport recorded only a trace of precipitation between June 16 and June 28, 2011.

Table E-3: Meteorological Data Capture – Valid Hours per Month

| Period | Meteorological Parameters – Data Recovery ¹ | | | | | | | | |
|-------------------------------|--|---------------------------|--|---------------------|---|--------------|--------------|--------------|-----------------|
| | Horizontal Wind Speed | Horizontal Wind Direction | Wind Direction Std. Dev. (Sigma Theta) | Vertical Wind Speed | Vertical Wind Speed Std. Dev. (Sigma Omega) | 2-M Temp | 10-M Temp | Delta-T | Solar Radiation |
| January 2011 | 721 | 722 | 722 | 240 | 240 | 743 | 743 | 743 | 720 |
| February 2011 | 583 | 582 | 582 | 581 | 581 | 634 | 668 | 634 | 657 |
| March 2011 | 644 | 644 | 644 | 677 | 677 | 0 | 733 | 0 | 731 |
| 1st Quarter | 1,948 | 1,948 | 1,948 | 1,498 | 1,498 | 1,377 | 2,144 | 1,377 | 2,108 |
| April 2011 | 716 | 711 | 711 | 691 | 691 | 0 | 716 | 0 | 713 |
| May 2011 | 688 | 681 | 681 | 668 | 668 | 0 | 688 | 0 | 742 |
| June 2011 | 665 | 665 | 665 | 683 | 683 | 683 | 683 | 683 | 714 |
| 2nd Quarter | 2,069 | 2,057 | 2,042 | 2,042 | 2,070 | 683 | 2,087 | 683 | 2,169 |
| July 2011 | 744 | 743 | 742 | 742 | 744 | 744 | 744 | 744 | 744 |
| August 2011 | 695 | 694 | 695 | 695 | 695 | 695 | 695 | 695 | 694 |
| September 2011 | 720 | 718 | 717 | 717 | 720 | 720 | 720 | 720 | 710 |
| 3rd Quarter | 2,159 | 2,155 | 2,154 | 2,154 | 2,159 | 2,159 | 2,159 | 2,159 | 2,148 |
| October 2011 | 743 | 743 | 743 | 541 | 541 | 743 | 743 | 743 | 730 |
| November 2011 | 567 | 710 | 710 | 666 | 666 | 710 | 710 | 709 | 700 |
| December 2011 | 741 | 741 | 741 | 293 | 293 | 741 | 741 | 741 | 735 |
| 4th Quarter | 2,051 | 2,194 | 2,194 | 1,500 | 1,500 | 2,194 | 2,194 | 2,193 | 2,165 |
| Year to Date | 8,227 | 8,354 | 8,354 | 7,194 | 7,194 | 6,413 | 8,584 | 6,412 | 8,590 |

Table E-4: Meteorological Data Capture – Percent Data Capture

| Period | Meteorological Parameters – Data Recovery ¹ | | | | | | | | |
|-------------------------------|--|---------------------------|--|-----------------------|---|-----------------------|-----------|-----------------------|-----------------|
| | Horizontal Wind Speed | Horizontal Wind Direction | Wind Direction Std. Dev. (Sigma Theta) | Vertical Wind Speed | Vertical Wind Speed Std. Dev. (Sigma Omega) | 2-M Temp | 10-M Temp | Delta-T | Solar Radiation |
| January 2011 | 97 | 97 | 97 | 32 | 32 | 100 | 100 | 100 | 97 |
| February 2011 | 87 | 87 | 87 | 86 | 86 | 94 | 99 | 94 | 98 |
| March 2011 | 87 | 87 | 87 | 91 | 91 | 0 | 99 | 0 | 98 |
| 1st Quarter | 90 | 90 | 90 | 69² | 69² | 64³ | 99 | 64³ | 98 |
| April 2011 | 99 | 99 | 99 | 96 | 96 | 0 | 99 | 0 | 99 |
| May 2011 | 92 | 92 | 92 | 90 | 90 | 0 | 92 | 0 | 100 |
| June 2011 | 92 | 92 | 92 | 95 | 95 | 95 | 95 | 95 | 99 |
| 2nd Quarter | 95 | 94 | 94 | 94 | 94 | 31³ | 96 | 31³ | 99 |
| July 2011 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 |
| August 2011 | 93 | 93 | 93 | 93 | 93 | 93 | 93 | 93 | 93 |
| September 2011 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 99 |
| 3rd Quarter | 98 | 98 | 98 | 98 | 98 | 98 | 98 | 98 | 97 |
| October 2011 | 100 | 100 | 100 | 73 | 73 | 100 | 100 | 100 | 98 |
| November 2011 | 79 | 99 | 99 | 93 | 93 | 99 | 99 | 98 | 97 |
| December 2011 | 100 | 100 | 100 | 39 | 39 | 100 | 100 | 100 | 99 |
| 4th Quarter | 93 | 99 | 99 | 68² | 68² | 99 | 99 | 99 | 98 |
| Year to Date | 94 | 95 | 95 | 82² | 82² | 73³ | 98 | 73³ | 98 |

¹ EPA PSD-quality meteorological monitoring standards require data capture of 90 percent or greater per quarter for four consecutive quarters.

² Quarterly data recovery was less than 90 percent during the first and fourth quarters due to episodes of rime ice build-up on sensor. Parameters are not mandatory inputs for dispersion modeling.

³ First and second quarter data capture and annual data capture for 2-meter temperature and delta T were less than 90 =due to a failed 2-meter aspirator fan. Problem was not resolved until June 1, 2011.

1. INTRODUCTION

1.1 PROJECT SUMMARY

Since April 9, 1999 (prior to construction of the Alpine Central Processing Facility), CPAI has operated an ambient air quality and meteorology monitoring station in Nuiqsut, Alaska, which is located on the Alaskan North Slope. The Nuiqsut Ambient Air Quality and Meteorological Monitoring Program is comprised of one station located at the northern edge of Nuiqsut approximately 400 meters north-northwest of the community electrical generators. Figure 1-2 shows an aerial image of Nuiqsut and depicts the location of the monitoring station. Currently, the Nuiqsut Monitoring Program is being conducted on a voluntary basis to document air quality in Nuiqsut. The data may also be used to support various ambient air quality impact analyses conducted for oil field development in the Colville Delta region.

The monitoring program consists of an ambient air quality monitoring station and a meteorological monitoring tower directly mounted to the air quality monitoring structure. The program is designed and operated in accordance with applicable Prevention of Significant Deterioration (PSD) regulations and guidance documents. The specific project objectives of the Monitoring Program are to:

- Collect data to document Nuiqsut air quality and address community concerns related to regional oilfield development.
- Establish a monitoring system to measure, with known accuracy and precision, meteorological parameters at the project site from ground level up to 10 meters.
- Provide required and relevant optional meteorological data for American Meteorological Society/EPA Regulatory Model Improvement Committee Model (AERMOD) modeling system.
- Establish a monitoring system to measure, with known bias and precision, the ambient concentrations of the criteria air quality pollutants: ozone (O₃), carbon monoxide (CO), nitrogen dioxide (NO₂), sulfur dioxide (SO₂), particulate matter with an aerodynamic diameter of 10 microns or less (PM₁₀), and particulate matter with an aerodynamic diameter of 2.5 microns or less (PM_{2.5}) to establish National Ambient Air Quality Standards (NAAQS) compliance status for the monitoring location.

The Nuiqsut station collects the following ambient air data:

- Oxides of nitrogen (NO₂, NO_x, and NO)
- Carbon monoxide (CO)
- Sulfur dioxide (SO₂)
- Ozone (O₃)
- Inhalable particulate matter less than 10 microns (PM₁₀)
- Inhalable particulate matter less than 2.5 microns (PM_{2.5})

The Nuiqsut station measures the following meteorological parameters:

- Air temperature, two and ten meters above ground level (degrees Celsius [$^{\circ}\text{C}$]);
- Horizontal wind speed (meters per second [m/s]);
- Horizontal wind direction (degrees [$^{\circ}$]);
- Vertical wind speed (meters per second [m/s]);
- Solar radiation (Watts per square meter [W/m^2]);

The Nuiqsut station calculates the following meteorological parameters:

- Temperature difference (ΔT , "Delta T" (degrees Celsius [$^{\circ}\text{C}$]), is calculated as temperature at 10 meters minus temperature at 2 meters);
- Horizontal wind direction standard deviation (Sigma Theta [σ_{θ}]).
- Vertical wind speed standard deviation (Sigma Omega [σ_{ω}]).

Data review and validation procedures and monitoring program data and measurement quality objectives (DQO and MQA) are provided in the Nuiqsut Ambient Air Quality and Meteorological Monitoring Station Quality Assurance Project Plans prepared by AECOM (August 2010) and a Nuiqsut QAPP submitted by SLR to ADEC in July 2011.

The community of Nuiqsut is located in the Colville River Delta region of the North Slope of Alaska. Figures 1-1 shows a detailed map of Nuiqsut while Figure 1-2 provides an aerial view of the Nuiqsut village. Figure 1-3 depicts the general location of the project area.




Figure 1-1: Local Map of Nuiqsut



Figure 1-2: Aerial Photo Showing Site Location




Figure 1-3: Area Map

1.2 MEASUREMENT METHODS TABLE

All instruments meet or exceed the U.S. Environmental Protection Agency (EPA) PSD requirements for range accuracies, thresholds, response times, resolutions, damping ratios, and other measures of instrument performance.

1.2.1 CONTINUOUS NO₂, O₃, CO AND SO₂ MONITORING

The gas analyzers used for the Nuiqsut Air Monitoring Station have been designated by EPA as either a Federal Equivalent Method (FEM) or Federal Reference Method (FRM) as defined in 40 CFR 53. Table 1-1 provides a summary of the measurement methods and parameters used for the Nuiqsut Ambient Air Monitoring Program.

Table 1-1: Gaseous Pollutant Measurement Parameters

| Parameter | Instrument | References | Units | Sampling Frequency | Sample Averaging |
|--|---|-------------------------------------|-------------------------|--------------------|------------------|
| Nitrogen Dioxide (NO₂)¹ | Thermo Scientific 42c Chemiluminescent NO _x gas analyzer | EPA reference method RFNA-1289-074 | Parts per million (ppm) | Continuous | 1-hour |
| Sulfur Dioxide (SO₂) | Thermo 43c Pulsed fluorescence SO ₂ gas analyzer | EPA equivalent method EQSA-0486-060 | Parts per million (ppm) | Continuous | 1-hour |
| Carbon Monoxide (CO) | Thermo 48i Gas filter correlation analyzer | EPA equivalent method RFCA-0981-054 | Parts per million (ppm) | Continuous | 1-hour |
| Ozone (O₃) | T-API T400 UV Photometric Ozone analyzer | EPA equivalent method EQOA-0992-087 | Parts per million (ppm) | Continuous | 1-hour |

¹ Total oxides of nitrogen (NO_x) and nitrogen Oxide (NO) are also measured.

1.2.2 CONTINUOUS PM₁₀ AND PM_{2.5} MONITORING

Monitoring for PM₁₀/PM_{2.5} data was conducted in accordance with the requirements and guidance in 40 CFR Parts 50, 53, and 58. Prior to March 3, 2011, the PM₁₀ monitoring was conducted using a Rupprecht & Patashnick Model 1400ab TEOM. The US EPA designation for this unit is FEM EQPM-1090-079. After March 3, 2011, both PM₁₀ and PM_{2.5} monitoring were conducted using the Met One Instruments, Inc. Model BAM-1020 Beta Attenuation Mass Monitors, which continuously measure ambient particulate concentrations using beta ray attenuation. The US EPA designations for these units are PM₁₀: FEM EQPM-0798-122 and PM_{2.5} Class III FEM EQPM-0308-170. For EPA reference method sampling, the PM_{2.5} sampler inlet system was configured with a BGI VSCC™ (Very Sharp Cut Cyclone) particle size separator.

CPAI participates in the North Slope air monitoring network that contains a PM_{2.5} collocation station in Deadhorse, Alaska. As such, filter-based samplers for assessing precision were not

run at Nuiqsut. Network precision statistics were evaluated using samples collocated at Deadhorse.

Block daily averages (24-hours) were obtained from the hourly measurements with the BAM-1020 samplers. Table 1-2 lists the particulate matter parameters measured and the frequency at which samples collected and recorded.

Table 1-2: PM Monitoring Measurement Parameters

| Parameter | Units | Sampling Schedule | Sample Period | Averaging Time |
|-------------------------------|---|----------------------|--|---------------------------------|
| PM ₁₀ ¹ | Micrograms per cubic meter (µg/m ³) | Continuous | 1-Hour ² | 24-Hour (Average) ² |
| PM _{2.5} | Micrograms per cubic meter (µg/m ³) | Continuous | 1-Hour ² | 24-Hour (Average) ² |
| Sample Volume | Cubic meters (m ³) | Every sampling event | Continuously up to 30 days (hourly checks) | Total volume over sample period |
| Flow Rate | Liters per min (LPM) | | | Average over sampling period |
| Ambient Temperature | Degrees Celsius (°C) | | | |
| Barometric Pressure | Millimeters of mercury (mm Hg) | | | |

¹ Applicable to both TEOM and BAM-1020 PM₁₀ samplers.

² 24-hour averages are obtained from the 1-hour measurements each day. A minimum of 18 hours must be available for a valid 24-hr average to be calculated.

1.2.3 METEOROLOGICAL MONITORING

The meteorological monitoring (wind speed, wind direction, vertical wind speed, ambient air temperature, and solar radiation) were conducted in a manner consistent with PSD criteria for surface meteorological data collection. The meteorological sensors met or exceeded the performance specifications stated in *Meteorological Monitoring Guidance for Regulatory Modeling Applications* (EPA-454/R-99-005). Table 1-3 lists the parameters measured, their reported units, sampling frequency, and sample averaging time.

Table 1-3: Meteorological Measurement Methods

| Parameter | Sensor Manufacturer/ Model Number | Measurement Method | Range | Accuracy | Sampling Frequency | Averaging Period |
|----------------------------------|--|---|-----------------------------|------------------------------|-------------------------------|-----------------------------|
| Ambient Temperature | Cimatronic Model 100093-2 | Triple element thermistor | -50 to +50°C | ± 0.1°C | 1 second | 1 hour |
| Horizontal Wind Speed | RM Young Co. 05305-AQ | Propeller, magnetically induced AC sine wave | 0 to 50 m/s | ±(0.2 m/s + 5% of actual) | 1 second | 1 hour |
| Wind Direction | RM Young Co. 05305-AQ | Light-weight vane, Low torque potentiometer | 0 to 360° | ± 3° | 1 second | 1 hour |
| Vertical Wind Speed | RM Young Co. 27106 | Propeller anemometer | -25 to 25 m/s | ±(0.2 m/s + 5% of actual) | 1 second | 1 hour |
| Solar Radiation | Eppley PSP | Precision thermopile pyranometer | 0 to 1,400 W/m ² | ± 2% | 1 second | 1 hour |

1.3 VARIATIONS FROM THE QAPP

During the 2010 monitoring year, the following variations from the approved Nuiqsut Ambient Air Quality and Meteorological Monitoring Quality Assurance Project Plan (QAPP) occurred:

Table 1-4: QAPP Variation Table

| Item / Procedure | Summary of QAPP Variation | Reason for Variation |
|---|---|--|
| The Nuiqsut Ambient Air Quality and Meteorological Monitoring Station QAPP submitted by AECOM in August 2010 stated that PM ₁₀ sampling is conducted using a Rupprecht & Patashnick Model 1400ab TEOM. | On March 3, 2011, the PM ₁₀ TEOM sampler was replaced with a Met One Instruments, Inc. BAM-1020 Beta Attenuation Mass Monitor. | The TEOM PM ₁₀ sampler was 12 years old and near the end of its life expectancy. The BAM-1020 PM ₁₀ sampler was chosen as a replacement for ease of operation and consistency among other SLR monitoring stations. |
| In the Nuiqsut QAPP submitted by SLR to ADEC in July 2011, it is stated that meteorological parameters to be measured would include relative humidity and barometric pressure. | Meteorological data for relative humidity and barometric pressure were not collected during the 2011 monitoring year. | The Nuiqsut station was not configured with relative humidity and barometric pressure sensors during the 2011 monitoring year. These parameters are not required for dispersion modeling. |

2. STATION PERFORMANCE SUMMARY

2.1 SIGNIFICANT PROJECT EVENTS

Table 2-1 summarizes the significant events that occurred at the Nuiqsut station relevant to the 2011 ambient air and meteorological monitoring year.

Table 2-1: Chronology of Significant Events

| Date | Event |
|----------------------------|---|
| January 1, 2011 | Start of monitoring year. |
| January 2, 2011 | High winds affect PM ₁₀ and PM _{2.5} instrument readings. 2 hours of PM ₁₀ data and 6 hours of PM _{2.5} data flagged invalid. |
| January 10-31, 2011 | Vertical wind speed data indicate the sensor froze from January 10 through January 31, 2011. Approximately 500 hours of data flagged invalid. Horizontal wind data indicate intermittent sensor freezing resulting in approximately 20 hours of data invalid. |
| January 31, 2011 | QC check performed on PM ₁₀ . |
| February 15, 2011 | Vertical wind speed data indicate sensor froze. 13 hours of vertical wind speed data flagged invalid. |
| February 17, 2011 | Multipoint calibrations performed on all ambient air analyzers; all passed. Rental NO _x analyzer replaced with repaired station NO _x analyzer. |
| February 17-March 10, 2011 | No valid precision checks for NO _x analyzer result in data invalidation. |
| February 18, 2011 | QC check performed on PM _{2.5} and PM ₁₀ . |
| February 18-23, 2011 | Zero air generator remained activated for six days. 118 hours of ambient gas data flagged invalid. |
| February 24, 2011 | Station calibrator malfunction results in invalid precision and span/zero checks for all gas analyzers. |
| February 25-March 4, 2011 | High winds damage vertical and horizontal wind sensors; repaired/replaced on March 4, 2011. Approximately 184 hours of horizontal wind data and 79 hours of vertical wind data flagged invalid. |
| February 27-June 1, 2011 | Two meter temperature and vertical temperature difference (Delta T) data indicate faulty two meter temperature aspirator. Aspirator not repaired until May 31, 2011. 2-meter temperature data are flagged invalid from February 27 through June 1, 2011, approximately 2,250 hours. |
| March 3, 2011 | New Ozone (O ₃) monitor, ozone calibrator, and Envidas data acquisition system (DAS) installed. Station PM ₁₀ analyzer (TEOM) was replaced with a new PM ₁₀ (BAM 1020 PM ₁₀) monitor. |
| March 4, 2011 | Calibrations of horizontal and vertical wind sensors and solar radiation sensor. |
| March 3-10, 2011 | No shelter temperature data resulting in approximately 175 hours of invalid ambient gas data for each analyzer. |
| March 10, 2011 | Multipoint calibrations performed on all ambient air analyzers; all passed. QC check performed on PM _{2.5} and PM ₁₀ . |
| March 12-13, 2011 | Ozone calibration malfunction results in 41 hours of invalid ozone data and invalid daily zero check. |

Table 2-1 Continued: Chronology of Significant Events

| Date | Event |
|------------------------|--|
| March 16, 2011 | Independent performance audit of ambient air analyzers conducted by AMS Tech, LLC. All instruments found to be operating within EPA PSD measurement quality limits. |
| March 17-April 1, 2011 | Ozone transfer standard was removed for recertification at SLR Anchorage. No ozone precision or span/zero checks were performed during this period. Six-day ozone transfer standard recertification performed at SLR Anchorage. Ozone transfer standard shipped back to Nuiqsut station and re-installed on April 1, 2011. Ozone calibration conducted; passed. |
| April 2, 2011 | QC check performed on PM _{2.5} and PM ₁₀ . |
| April 5-12, 2011 | Approximately 170 hours of PM ₁₀ and 75 hours of PM _{2.5} data lost due to BAM-1020 communication problems. |
| April 13, 2011 | O ₃ calibrations did not properly execute due to O ₃ calibrator communication problems resulting in 16 hours of invalid data. |
| April 28, 2011 | NO _x calibration; passed. |
| May 5-9, 2011 | Approximately 70 hours of PM ₁₀ data invalidated due to readings below sampler detection limits. |
| May 23, 2011 | QC check performed on PM _{2.5} and PM ₁₀ . |
| May 29- June 1, 2011 | Elevator installed on meteorological tower resulting in approximately 75 hours of invalid data for all meteorological sensors. Calibrations performed on all gas analyzers and meteorological instruments; all passed. Aspirated shields replaced on temperature sensors to correct temperature measurement problem. |
| June 2-3, 2011 | Independent performance audit of all ambient air analyzers and meteorological sensors conducted by AMS Tech, LLC. All instruments were found to be operating within EPA PSD measurement quality limits. |
| June 13-19, 2011 | Ozone analyzer pump failure resulting in approximately 146 hours of invalid data. Analyzer returned to service June 19 and calibration conducted; passed. |
| June 28, 2011 | High PM ₁₀ concentrations were measured on June 28, 2011 during a period of high winds from the east northeast direction. The average wind speeds were 10-12 m/s with wind directions between 53-77 degrees (clockwise from north) during the period of high PM ₁₀ concentrations. These ENE winds were likely to have transported dust from the Colville River delta, since there was no snow cover at this time. Conditions were also quite dry at the time, as the nearby Deadhorse airport recorded only a trace of precipitation between June 16 and June 28. Calibration performed on CO and SO ₂ analyzers; both passed. |
| July 1, 2011 | QC check performed on PM _{2.5} and PM ₁₀ . |
| July 5, 2011 | QC check performed on PM _{2.5} and PM ₁₀ . |
| July 1-5, 2011 | Background check performed on BAM 1020-2243 resulting in a loss of data from 1200 hours July 1 to 1300 hours July 5. |
| July 23, 2011 | QC check performed on PM _{2.5} and PM ₁₀ . |
| August 1, 2011 | QC check performed on PM _{2.5} and PM ₁₀ . |

Table 2-1 Continued: Chronology of Significant Events

| Date | Event |
|---------------------------------|--|
| August 18, 2011 | Calibration verification performed on all ambient air analyzers; all passed. Independent performance audit of ambient air analyzers conducted by AMS Tech, LLC. All instruments were found to be operating within EPA PSD measurement quality limits. |
| August 26-29, 2011 | Connection on equipment temporarily failed due to power outage. QC check performed on PM _{2.5} and PM ₁₀ ; all passed. |
| September 2, 2011 | QC check performed on PM _{2.5} and PM ₁₀ . |
| September 11, 2011 | QC check performed on PM _{2.5} and PM ₁₀ . |
| September 20, 2011 | QC check performed on PM _{2.5} and PM ₁₀ . |
| September 23, 2011 | QC check performed on PM _{2.5} and PM ₁₀ . |
| September 26, 2011 | QC check performed on PM _{2.5} and PM ₁₀ . |
| October 4, 2011 | Ozone calibration performed; passed. |
| October 3 - 12, 2011 | Vertical wind sensor frozen resulting in the loss of approximately 200 hours of data. |
| November 7 - 8, 2011 | Independent performance audit of all ambient air analyzers and meteorological sensors conducted by AMS Tech, LLC. All instruments were found to be operating within EPA PSD measurement quality limits. Shelter temperature dropped below 20° C, resulting in invalidation of gas analyzer data. |
| November 8, 2011 | Annual maintenance on BAM PM sensors and calibration of all gas analyzers; all passed. |
| November 18 - 22, 2011 | Horizontal wind sensor frozen resulting in the loss of approximately 85 hours of data. |
| November 26 - 28, 2011 | Horizontal wind data invalidated due to Envidas error resulting in the loss of approximately 46 hours of data. |
| November 27, 2011 | Approximately 14 hours of PM ₁₀ data invalidated due to readings below sampler detection limits. |
| November 30 - December 19, 2011 | Propeller on vertical wind sensor broken, resulting in a loss of approximately 484 hours of data. New propeller installed. |
| December 4 - 5, 2011 | SO ₂ pump failure, resulting in a loss of data. |
| December 28, 2011 | Technical systems audit conducted by AMS Tech, LLC.; all aspects of the monitoring project were in order. |
| December 31, 2011 | End of monitoring year. |

2.2 MISSING, INVALID AND ADJUSTED DATA

Table 2-2 lists the quantities of data that were flagged according to EPA criteria, yet not removed from the refined final data set. All flagged data were carefully examined, but generally remained in the reduced data unless dictated by certain circumstances, including: values outside the normal range of variation; consecutive repetitive values recorded for an unidentified reason; maintenance activity at the site, and impairing damage to sensors.

Table 2-2: Percentage of Final Data Set Flagged

| Parameter | Flagging Criteria ¹ | Percent Flagged |
|-------------------------------|---|-----------------|
| Wind Speed | Value is < 0 m/s | 0.0% |
| | Value is > 25 m/s | 0.0% |
| | < 0.1 m/s variation for 3 consecutive hours | 2.7% |
| | < 0.5 m/s variation for 12 consecutive hours | 1.6% |
| Wind Direction | Value is < 0°, > 360° | 0.0% |
| | < 1° variation over 3 consecutive hours | 0.0% |
| | < 10° variation over 18 consecutive hours | 1.1% |
| Temperature (2 meters) | > 5°C variation from previous hour | 0.2% |
| | < 0.5°C variation for 12 consecutive hours | 0.4% |
| | Value is > record high, < record low | 0.0% |
| Temperature (10 meters) | > 5°C variation from previous hour | 0.2% |
| | < 0.5°C variation for 12 consecutive hours | 0.8% |
| | Value is > record high, < record low | 0.0% |
| Temperature Difference, ΔT | Value is > 0.8°C during the daytime | 0.3% |
| | Value is < -0.8°C during the night | 0.0% |
| | Value is > 5°C, < -3°C | 0.0% |
| Solar Radiation | > 0 w/m ² at night | 1.3% |
| | Greater than the maximum possible value for date and latitude | 0.1% |

Based upon Table 8-4: Suggested Data Screening Criteria in *Meteorological Monitoring Guidance for Regulatory Modeling Applications* (EPA-454/R-99-005).

2.3 NETWORK DATA COMPLETENESS

Data completeness is a measure of the amount of data actually collected compared to the amount of data that could have been collected. Data completeness was calculated by dividing the number of valid hours of data by the total number of hours during the monitoring period. The data quality objective (DQO) for data completeness for air quality data is 80 percent per calendar quarter, and 90 percent for meteorological data per calendar quarter.

The Nuiqsut ambient air and meteorological monitoring station met all PSD requirements during the monitoring year with the following notable exceptions:

- First quarter data recovery for NO₂ was less than eighty percent due to analyzer down time during station rebuild and a failure to meet PSD precision check acceptance criteria between February 17, 2011 and March 11, 2011. The NO₂ analyzer was recalibrated and restored to proper operation on March 10, 2011. Valid NO₂ data was established with the passing March 11, 2011 calibrations.
- Vertical wind speed and vertical wind speed standard deviation (sigma omega) data recovery was less than ninety percent during the first and fourth quarters of the monitoring year due to episodes of rime ice build-up on the sensor. These parameters are not mandatory inputs for regulatory dispersion modeling.
- First and second quarter data recovery for two-meter temperature and delta temperature was less than ninety percent due to a faulty aspirator fan in the two-meter temperature sensor. This problem was not resolved until June 1, 2011.

Annual and quarterly data completeness for ambient air and meteorological parameters are provided in Tables 2-3 and 2-4, respectively. Calculations for determining data completeness are provided in Appendix A. Fully validated data for all parameters are provided in Appendix D.

Table 2-3: Ambient Air Quality Data Capture Percent

| Period | Pollutants – Data Recovery ¹ | | | | | |
|-------------------------------|---|-----------------|-----------|----------------|-------------------|------------------|
| | NO ₂ | SO ₂ | CO | O ₃ | PM _{2.5} | PM ₁₀ |
| January 2011 | 99 | 99 | 99 | 99 | 100 | 100 |
| February 2011 | 57 | 81 | 81 | 81 | 100 | 100 |
| March 2011 | 66 | 75 | 75 | 69 | 94 | 81 |
| 1st Quarter | 74² | 85 | 85 | 83 | 98 | 93 |
| April 2011 | 98 | 98 | 98 | 96 | 87 | 70 |
| May 2011 | 98 | 98 | 98 | 98 | 100 | 81 |
| June 2011 | 98 | 98 | 98 | 77 | 100 | 97 |
| 2nd Quarter | 98 | 98 | 98 | 91 | 96 | 82 |
| July 2011 | 99 | 99 | 99 | 99 | 100 | 84 |
| August 2011 | 90 | 82 | 85 | 86 | 100 | 100 |
| September 2011 | 98 | 91 | 98 | 98 | 100 | 97 |
| 3rd Quarter | 96 | 91 | 94 | 94 | 100 | 93 |
| October 2011 | 99 | 90 | 99 | 99 | 94 | 90 |
| November 2011 | 95 | 91 | 95 | 95 | 100 | 70 |
| December 2011 | 95 | 90 | 95 | 95 | 90 | 90 |
| 4th Quarter | 97 | 90 | 97 | 96 | 95 | 84 |
| Monitoring Year | 91 | 91 | 94 | 91 | 97 | 88 |

¹ EPA PSD-quality ambient air monitoring standards require data capture of 80 percent or greater per quarter for four consecutive quarters.

² Quarterly data recovery for NO₂ was less than 80 percent during the first quarter due to analyzer down time during station rebuild and a failure to meet PSD precision check acceptance criteria between 2/17/2011 and 3/11/2011. The NO₂ analyzer was recalibrated and restored to proper operation on 3/10/2011. Valid NO₂ data was established with 3/11/2011 calibrations.

Table 2-4: Meteorological Data Capture Percent

| Period | Meteorological Parameters – Data Recovery ¹ | | | | | | | | |
|-------------------------------|--|---------------------------|--|-----------------------|---|-----------------------|-----------|-----------------------|-----------------|
| | Horizontal Wind Speed | Horizontal Wind Direction | Wind Direction Std. Dev. (Sigma Theta) | Vertical Wind Speed | Vertical Wind Speed Std. Dev. (Sigma Omega) | 2-M Temp | 10-M Temp | Delta-T | Solar Radiation |
| January 2011 | 97 | 97 | 97 | 32 | 32 | 100 | 100 | 100 | 97 |
| February 2011 | 87 | 87 | 87 | 86 | 86 | 94 | 99 | 94 | 98 |
| March 2011 | 87 | 87 | 87 | 91 | 91 | 0 | 99 | 0 | 98 |
| 1st Quarter | 90 | 90 | 90 | 69² | 69² | 64³ | 99 | 64³ | 98 |
| April 2011 | 99 | 99 | 99 | 96 | 96 | 0 | 99 | 0 | 99 |
| May 2011 | 92 | 92 | 92 | 90 | 90 | 0 | 92 | 0 | 100 |
| June 2011 | 92 | 92 | 92 | 95 | 95 | 95 | 95 | 95 | 99 |
| 2nd Quarter | 95 | 94 | 94 | 94 | 94 | 31³ | 96 | 31³ | 99 |
| July 2011 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 |
| August 2011 | 93 | 93 | 93 | 93 | 93 | 93 | 93 | 93 | 93 |
| September 2011 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 99 |
| 3rd Quarter | 98 | 98 | 98 | 98 | 98 | 98 | 98 | 98 | 97 |
| October 2011 | 100 | 100 | 100 | 73 | 73 | 100 | 100 | 100 | 98 |
| November 2011 | 79 | 99 | 99 | 93 | 93 | 99 | 99 | 98 | 97 |
| December 2011 | 100 | 100 | 100 | 39 | 39 | 100 | 100 | 100 | 99 |
| 4th Quarter | 93 | 99 | 99 | 68² | 68² | 99 | 99 | 99 | 98 |
| Year to Date | 94 | 95 | 95 | 82² | 82² | 73³ | 98 | 73³ | 98 |

¹ EPA PSD-quality meteorological monitoring standards require data capture of 90 percent or greater per quarter for four consecutive quarters.

² Quarterly data recovery was less than 90 percent during the first and fourth quarters due to episodes of rime ice build-up on sensor. Parameters are not mandatory inputs for dispersion modeling.

³ First and second quarter data capture and annual data capture for 2-meter temperature and delta T were less than 90 =due to a failed 2-meter aspirator fan. Problem was not resolved until June 1, 2011.

2.4 PRECISION STATISTICS

2.4.1 MONITORING NETWORK PRECISION STATISTICS

Precision statistics were determined using the methods outlined in 40 Code of Federal Regulation, Part 58 (40 CFR 58), Appendix A. Valid precision data for ambient air monitors (O₃, SO₂, NO₂, CO) were collected at least once every two weeks, meeting the critical validation criteria outlined in the monitoring program QAPP. Continuous low-volume PM_{2.5} and PM₁₀ samplers are not required to have collocated precision comparisons. Quarterly precision statistics for each criteria pollutant are provided in Tables 2-5 through 2-20.

EPA recommends that precision statistics for PM_{2.5} should only be calculated for collocated samples if both the collocated and the primary sample concentrations are greater than or equal to 3 µg/m³. As proposed in the Deadhorse PM_{2.5} Monitoring Program QAPP, precision statistics for this monitoring project were calculated for collocated samples if both the collocated and the primary sample concentrations were greater than or equal to 2 µg/m³. Quarterly network PM precision statistics are presented in Table 2-21.

Table 2-5: 1st Quarter O₃ Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 3-Jan-10 | auto | 0.0841 | 0.0848 | -0.83 | 20 | 0.70 | 0.96 | 2.58 | -1.18 | 1.23 | +1.18 |
| 6-Jan-11 | auto | 0.0864 | 0.0856 | 0.93 | | | | | | | |
| 9-Jan-11 | auto | 0.0834 | 0.0828 | 0.72 | | | | | | | |
| 12-Jan-11 | auto | 0.0851 | 0.0838 | 1.55 | | | | | | | |
| 15-Jan-11 | auto | 0.0808 | 0.0807 | 0.12 | | | | | | | |
| 18-Jan-11 | auto | 0.0800 | 0.0798 | 0.25 | | | | | | | |
| 21-Jan-11 | auto | 0.0839 | 0.0836 | 0.36 | | | | | | | |
| 24-Jan-11 | auto | 0.0814 | 0.0818 | -0.49 | | | | | | | |
| 27-Jan-11 | auto | 0.0861 | 0.0858 | 0.35 | | | | | | | |
| 30-Jan-11 | auto | 0.0829 | 0.0828 | 0.12 | | | | | | | |
| 2-Feb-11 | auto | 0.0856 | 0.0837 | 2.27 | | | | | | | |
| 5-Feb-11 | auto | 0.0851 | 0.0848 | 0.35 | | | | | | | |
| 8-Feb-11 | auto | 0.0851 | 0.0848 | 0.35 | | | | | | | |
| 11-Feb-11 | auto | 0.0820 | 0.0808 | 1.49 | | | | | | | |
| 14-Feb-11 | auto | 0.0841 | 0.0838 | 0.36 | | | | | | | |
| 17-Feb-11 | auto | 0.0834 | 0.0829 | 0.60 | | | | | | | |
| 21-Feb-11 | auto | 0.0868 | 0.0855 | 1.52 | | | | | | | |
| 27-Feb-11 | auto | 0.0812 | 0.0815 | -0.37 | | | | | | | |
| 2-Mar-11 | auto | 0.0844 | 0.0835 | 1.08 | | | | | | | |
| 12-Mar-11 | auto | 0.0826 | 0.0800 | 3.25 | | | | | | | |

¹Acceptance criteria: ≤ 7%

²Acceptance criteria: ≤ ±7%

Table 2-6: 2nd Quarter O₃ Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 2-Apr-11 | auto | 0.0927 | 0.0900 | 3.00 | 12 | 3.25 | 0.42 | 4.08 | 2.42 | 0.60 | +3.47 |
| 9-Apr-11 | auto | 0.0925 | 0.0900 | 2.78 | | | | | | | |
| 16-Apr-11 | auto | 0.0927 | 0.0900 | 3.00 | | | | | | | |
| 23-Apr-11 | auto | 0.0925 | 0.0900 | 2.78 | | | | | | | |
| 30-Apr-11 | auto | 0.0927 | 0.0900 | 3.00 | | | | | | | |
| 7-May-11 | auto | 0.0930 | 0.0900 | 3.33 | | | | | | | |
| 14-May-11 | auto | 0.0930 | 0.0900 | 3.11 | | | | | | | |
| 21-May-11 | auto | 0.0929 | 0.0900 | 3.22 | | | | | | | |
| 28-May-11 | auto | 0.0936 | 0.0900 | 4.00 | | | | | | | |
| 4-Jun-11 | auto | 0.0928 | 0.0900 | 3.11 | | | | | | | |
| 11-Jun-11 | auto | 0.0936 | 0.0900 | 4.00 | | | | | | | |
| 25-Jun-11 | auto | 0.0933 | 0.0900 | 3.67 | | | | | | | |

¹Acceptance criteria: ≤ 7%

²Acceptance criteria: ≤ ±7%

Table 2-7: 3rd Quarter O₃ Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 2-Jul-11 | auto | 0.0934 | 0.0900 | 3.78 | 13 | 3.96 | 0.56 | 5.07 | 2.86 | 0.77 | +4.24 |
| 9-Jul-11 | auto | 0.0934 | 0.0900 | 3.78 | | | | | | | |
| 16-Jul-11 | auto | 0.0938 | 0.0900 | 4.22 | | | | | | | |
| 23-Jul-11 | auto | 0.0934 | 0.0900 | 3.78 | | | | | | | |
| 30-Jul-11 | auto | 0.0934 | 0.0900 | 3.78 | | | | | | | |
| 6-Aug-11 | auto | 0.0929 | 0.0900 | 3.22 | | | | | | | |
| 13-Aug-11 | auto | 0.0933 | 0.0900 | 3.67 | | | | | | | |
| 23-Aug-11 | auto | 0.0930 | 0.0900 | 3.33 | | | | | | | |
| 3-Sep-11 | auto | 0.0935 | 0.0900 | 3.89 | | | | | | | |
| 10-Sep-11 | auto | 0.0939 | 0.0900 | 4.33 | | | | | | | |
| 17-Sep-11 | auto | 0.0940 | 0.0900 | 4.44 | | | | | | | |
| 22-Sep-11 | auto | 0.0935 | 0.0900 | 3.86 | | | | | | | |
| 29-Sep-11 | auto | 0.0949 | 0.0900 | 5.42 | | | | | | | |

¹Acceptance criteria: ≤ 7%

²Acceptance criteria: ≤ ±7%

Table 2-8: 4th Quarter O₃ Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 6-Oct-11 | auto | 0.0908 | 0.0900 | 1.47 | 14 | -0.09 | 1.56 | 2.98 | -3.15 | 2.12 | 1.68 |
| 13-Oct-11 | auto | 0.0911 | 0.0900 | 1.31 | | | | | | | |
| 20-Oct-11 | auto | 0.0913 | 0.0900 | 1.72 | | | | | | | |
| 25-Oct-11 | auto | 0.0912 | 0.0900 | 1.47 | | | | | | | |
| 27-Oct-11 | auto | 0.0916 | 0.0900 | -0.94 | | | | | | | |
| 3-Nov-11 | auto | 0.0913 | 0.0900 | -1.92 | | | | | | | |
| 10-Nov-11 | auto | 0.0892 | 0.0900 | -1.94 | | | | | | | |
| 17-Nov-11 | auto | 0.0883 | 0.0900 | -2.39 | | | | | | | |
| 24-Nov-11 | auto | 0.0883 | 0.0900 | -1.94 | | | | | | | |
| 1-Dec-11 | auto | 0.0879 | 0.0900 | 1.19 | | | | | | | |
| 8-Dec-11 | auto | 0.0883 | 0.0900 | -0.08 | | | | | | | |
| 15-Dec-11 | auto | 0.0911 | 0.0900 | -1.19 | | | | | | | |
| 22-Dec-11 | auto | 0.0899 | 0.0900 | 1.47 | | | | | | | |
| 29-Dec-11 | auto | 0.0889 | 0.0900 | 1.31 | | | | | | | |

¹Acceptance criteria: ≤ 7%

²Acceptance criteria: ≤ ±7%

Table 2-9: 1st Quarter SO₂ Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 3-Jan-10 | auto | 0.0890 | 0.0940 | -5.32 | 22 | -3.80 | 1.66 | -0.55 | -7.05 | 2.09 | -4.41 |
| 6-Jan-11 | auto | 0.0920 | 0.0940 | -2.13 | | | | | | | |
| 9-Jan-11 | auto | 0.0900 | 0.0940 | -4.26 | | | | | | | |
| 12-Jan-11 | auto | 0.0910 | 0.0940 | -3.19 | | | | | | | |
| 15-Jan-11 | auto | 0.0930 | 0.0940 | -1.06 | | | | | | | |
| 18-Jan-11 | auto | 0.0910 | 0.0950 | -4.21 | | | | | | | |
| 21-Jan-11 | auto | 0.0900 | 0.0940 | -4.26 | | | | | | | |
| 24-Jan-11 | auto | 0.0920 | 0.0940 | -2.13 | | | | | | | |
| 27-Jan-11 | auto | 0.0900 | 0.0940 | -4.26 | | | | | | | |
| 30-Jan-11 | auto | 0.0910 | 0.0940 | -3.19 | | | | | | | |
| 2-Feb-11 | auto | 0.0920 | 0.0940 | -2.13 | | | | | | | |
| 5-Feb-11 | auto | 0.0920 | 0.0940 | -2.13 | | | | | | | |
| 8-Feb-11 | auto | 0.0890 | 0.0940 | -5.32 | | | | | | | |
| 11-Feb-11 | auto | 0.0890 | 0.0940 | -5.32 | | | | | | | |
| 14-Feb-11 | auto | 0.0910 | 0.0940 | -3.19 | | | | | | | |
| 17-Feb-11 | auto | 0.0920 | 0.0940 | -2.13 | | | | | | | |
| 21-Feb-11 | auto | 0.0850 | 0.0910 | -6.59 | | | | | | | |
| 27-Feb-11 | auto | 0.0840 | 0.0910 | -7.69 | | | | | | | |
| 2-Mar-11 | auto | 0.0860 | 0.0910 | -5.49 | | | | | | | |
| 12-Mar-11 | auto | 0.0780 | 0.0810 | -3.70 | | | | | | | |
| 19-Mar-11 | auto | 0.0789 | 0.0810 | -2.59 | | | | | | | |
| 26-Mar-11 | auto | 0.0783 | 0.0810 | -3.33 | | | | | | | |

¹Acceptance criteria: ≤ 10%

²Acceptance criteria: ≤ ±10%

Table 2-10: 2nd Quarter SO₂ Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 2-Apr-11 | auto | 0.0794 | 0.0810 | -1.98 | 13 | -3.32 | 1.40 | -0.59 | -6.06 | 1.93 | -4.01 |
| 9-Apr-11 | auto | 0.0782 | 0.0810 | -3.46 | | | | | | | |
| 16-Apr-11 | auto | 0.0787 | 0.0810 | -2.84 | | | | | | | |
| 23-Apr-11 | auto | 0.0803 | 0.0810 | -0.86 | | | | | | | |
| 30-Apr-11 | auto | 0.0799 | 0.0810 | -1.36 | | | | | | | |
| 7-May-11 | auto | 0.0790 | 0.0810 | -2.10 | | | | | | | |
| 14-May-11 | auto | 0.0780 | 0.0810 | -3.58 | | | | | | | |
| 21-May-11 | auto | 0.0772 | 0.0810 | -4.69 | | | | | | | |
| 28-May-11 | auto | 0.0774 | 0.0810 | -4.44 | | | | | | | |
| 4-Jun-11 | auto | 0.0780 | 0.0810 | -3.70 | | | | | | | |
| 11-Jun-11 | auto | 0.0776 | 0.0810 | -4.20 | | | | | | | |
| 18-Jun-11 | auto | 0.0772 | 0.0810 | -4.69 | | | | | | | |
| 25-Jun-11 | auto | 0.0767 | 0.0810 | -5.31 | | | | | | | |

¹Acceptance criteria: ≤ 10%

²Acceptance criteria: ≤ ±10%

Table 2-11: 3rd Quarter SO₂ Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 2-Jul-11 | auto | 0.0783 | 0.0810 | -3.33 | 14 | -3.29 | 0.99 | -1.35 | -5.23 | 1.35 | -3.76 |
| 9-Jul-11 | auto | 0.0787 | 0.0810 | -2.84 | | | | | | | |
| 16-Jul-11 | auto | 0.0766 | 0.0810 | -5.43 | | | | | | | |
| 23-Jul-11 | auto | 0.0776 | 0.0810 | -4.20 | | | | | | | |
| 30-Jul-11 | auto | 0.0784 | 0.0810 | -3.21 | | | | | | | |
| 6-Aug-11 | auto | 0.0784 | 0.0810 | -3.21 | | | | | | | |
| 13-Aug-11 | auto | 0.0785 | 0.0810 | -3.09 | | | | | | | |
| 23-Aug-11 | auto | 0.0770 | 0.0810 | -4.94 | | | | | | | |
| 31-Aug-11 | auto | 0.0791 | 0.0810 | -2.35 | | | | | | | |
| 3-Sep-11 | auto | 0.0785 | 0.0810 | -3.09 | | | | | | | |
| 10-Sep-11 | auto | 0.0796 | 0.0810 | -1.73 | | | | | | | |
| 17-Sep-11 | auto | 0.0790 | 0.0810 | -2.47 | | | | | | | |
| 22-Sep-11 | auto | 0.0788 | 0.0810 | -2.76 | | | | | | | |
| 29-Sep-11 | auto | 0.0782 | 0.0810 | -3.46 | | | | | | | |

¹Acceptance criteria: ≤ 10%

²Acceptance criteria: ≤ ±10%

Table 2-12: 4th Quarter SO₂ Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 6-Oct-11 | auto | 0.0777 | 0.0810 | -4.06 | 14 | -3.03 | 1.17 | -0.73 | -5.33 | 1.60 | -3.58 |
| 13-Oct-11 | auto | 0.0779 | 0.0810 | -3.83 | | | | | | | |
| 20-Oct-11 | auto | 0.0785 | 0.0810 | -3.07 | | | | | | | |
| 25-Oct-11 | auto | 0.0796 | 0.0810 | -1.79 | | | | | | | |
| 27-Oct-11 | auto | 0.0778 | 0.0810 | -3.94 | | | | | | | |
| 3-Nov-11 | auto | 0.0775 | 0.0810 | -4.31 | | | | | | | |
| 10-Nov-11 | auto | 0.0807 | 0.0810 | -0.39 | | | | | | | |
| 17-Nov-11 | auto | 0.0791 | 0.0810 | -2.36 | | | | | | | |
| 24-Nov-11 | auto | 0.0794 | 0.0810 | -2.00 | | | | | | | |
| 1-Dec-11 | auto | 0.0784 | 0.0810 | -3.27 | | | | | | | |
| 8-Dec-11 | auto | 0.0774 | 0.0810 | -4.41 | | | | | | | |
| 15-Dec-11 | auto | 0.0789 | 0.0810 | -2.55 | | | | | | | |
| 22-Dec-11 | auto | 0.0777 | 0.0810 | -4.07 | | | | | | | |
| 29-Dec-11 | auto | 0.0791 | 0.0810 | -2.35 | | | | | | | |

¹Acceptance criteria: ≤ 10%

²Acceptance criteria: ≤ ±10%

Table 2-13: 1st Quarter NO₂ Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 3-Jan-10 | auto | 0.0990 | 0.1050 | -5.71 | 19 | -3.96 | 1.99 | -0.06 | -7.85 | 2.56 | -4.75 |
| 6-Jan-11 | auto | 0.0980 | 0.1030 | -4.85 | | | | | | | |
| 9-Jan-11 | auto | 0.1000 | 0.1040 | -3.85 | | | | | | | |
| 12-Jan-11 | auto | 0.1010 | 0.1050 | -3.81 | | | | | | | |
| 15-Jan-11 | auto | 0.1010 | 0.1050 | -3.81 | | | | | | | |
| 18-Jan-11 | auto | 0.1010 | 0.1050 | -3.81 | | | | | | | |
| 21-Jan-11 | auto | 0.1010 | 0.1040 | -2.88 | | | | | | | |
| 24-Jan-11 | auto | 0.1000 | 0.1040 | -3.85 | | | | | | | |
| 27-Jan-11 | auto | 0.0990 | 0.1040 | -4.81 | | | | | | | |
| 30-Jan-11 | auto | 0.1010 | 0.1040 | -2.88 | | | | | | | |
| 2-Feb-11 | auto | 0.1000 | 0.1060 | -5.66 | | | | | | | |
| 5-Feb-11 | auto | 0.1000 | 0.1050 | -4.76 | | | | | | | |
| 8-Feb-11 | auto | 0.1010 | 0.1030 | -1.94 | | | | | | | |
| 11-Feb-11 | auto | 0.1000 | 0.1040 | -3.85 | | | | | | | |
| 14-Feb-11 | auto | 0.1020 | 0.1050 | -2.86 | | | | | | | |
| 17-Feb-11 | auto | 0.1010 | 0.1030 | -1.94 | | | | | | | |
| 2-Mar-11 | auto | 0.1130 | 0.1260 | -10.32 | | | | | | | |
| 12-Mar-11 | auto | 0.0915 | 0.0924 | -0.97 | | | | | | | |
| 26-Mar-11 | auto | 0.0814 | 0.0836 | -2.63 | | | | | | | |

¹Acceptance criteria: ≤ 10%

²Acceptance criteria: ≤ ±10%

Table 2-14: 2nd Quarter NO₂ Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 2-Apr-11 | auto | 0.0835 | 0.0841 | -0.71 | 13 | 0.21 | 1.90 | 3.92 | -3.51 | 2.62 | ±2.00 |
| 9-Apr-11 | auto | 0.0838 | 0.0846 | -0.95 | | | | | | | |
| 16-Apr-11 | auto | 0.0898 | 0.0884 | 1.58 | | | | | | | |
| 23-Apr-11 | auto | 0.0887 | 0.0890 | -0.34 | | | | | | | |
| 30-Apr-11 | auto | 0.0879 | 0.0883 | -0.45 | | | | | | | |
| 7-May-11 | auto | 0.0870 | 0.0870 | 0.58 | | | | | | | |
| 14-May-11 | auto | 0.0880 | 0.0930 | -5.17 | | | | | | | |
| 21-May-11 | auto | 0.0880 | 0.0871 | 1.03 | | | | | | | |
| 28-May-11 | auto | 0.0880 | 0.0874 | 0.67 | | | | | | | |
| 4-Jun-11 | auto | 0.0748 | 0.0737 | 1.47 | | | | | | | |
| 11-Jun-11 | auto | 0.0751 | 0.0735 | 2.15 | | | | | | | |
| 18-Jun-11 | auto | 0.0748 | 0.0737 | 1.48 | | | | | | | |
| 25-Jun-11 | auto | 0.0751 | 0.0741 | 1.36 | | | | | | | |

¹Acceptance criteria: ≤ 10%

²Acceptance criteria: ≤ ±10%

Table 2-15: 3rd Quarter NO₂ Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 2-Jul-11 | auto | 0.0735 | 0.0734 | 0.23 | 13 | 0.94 | 0.70 | 2.32 | -0.43 | 0.97 | +1.30 |
| 9-Jul-11 | auto | 0.0751 | 0.0746 | 0.66 | | | | | | | |
| 16-Jul-11 | auto | 0.0732 | 0.0726 | 0.82 | | | | | | | |
| 23-Jul-11 | auto | 0.0737 | 0.0731 | 0.82 | | | | | | | |
| 30-Jul-11 | auto | 0.0740 | 0.0722 | 2.49 | | | | | | | |
| 6-Aug-11 | auto | 0.0742 | 0.0732 | 1.38 | | | | | | | |
| 13-Aug-11 | auto | 0.0745 | 0.0735 | 1.44 | | | | | | | |
| 23-Aug-11 | auto | 0.0695 | 0.0687 | 1.09 | | | | | | | |
| 31-Aug-11 | auto | 0.0722 | 0.0711 | 1.47 | | | | | | | |
| 3-Sep-11 | auto | 0.0710 | 0.0706 | 0.61 | | | | | | | |
| 10-Sep-11 | auto | 0.0733 | 0.0725 | 1.10 | | | | | | | |
| 17-Sep-11 | auto | 0.0747 | 0.0743 | 0.53 | | | | | | | |
| 29-Sep-11 | auto | 0.0748 | 0.0751 | -0.41 | | | | | | | |

¹Acceptance criteria: ≤ 10%

²Acceptance criteria: ≤ ±10%

Table 2-16: 4th Quarter NO₂ Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 6-Oct-11 | auto | 0.0749 | 0.0727 | 2.98 | 14 | 3.62 | 1.12 | 5.81 | 1.43 | 1.52 | +4.15 |
| 13-Oct-11 | auto | 0.0760 | 0.0738 | 2.93 | | | | | | | |
| 20-Oct-11 | auto | 0.0762 | 0.0747 | 2.03 | | | | | | | |
| 25-Oct-11 | auto | 0.0757 | 0.0733 | 3.31 | | | | | | | |
| 27-Oct-11 | auto | 0.0758 | 0.0739 | 2.61 | | | | | | | |
| 3-Nov-11 | auto | 0.0771 | 0.0752 | 2.63 | | | | | | | |
| 10-Nov-11 | auto | 0.0755 | 0.0728 | 3.72 | | | | | | | |
| 17-Nov-11 | auto | 0.0798 | 0.0768 | 3.96 | | | | | | | |
| 24-Nov-11 | auto | 0.0774 | 0.0750 | 3.27 | | | | | | | |
| 1-Dec-11 | auto | 0.0771 | 0.0749 | 2.97 | | | | | | | |
| 8-Dec-11 | auto | 0.0772 | 0.0737 | 4.70 | | | | | | | |
| 15-Dec-11 | auto | 0.0789 | 0.0756 | 4.37 | | | | | | | |
| 22-Dec-11 | auto | 0.0791 | 0.0752 | 5.17 | | | | | | | |
| 29-Dec-11 | auto | 0.0785 | 0.0741 | 6.05 | | | | | | | |

¹Acceptance criteria: ≤ 10%

²Acceptance criteria: ≤ ±10%

Table 2-17: 1st Quarter CO Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 3-Jan-10 | auto | 7.13 | 6.89 | 3.47 | 22 | 4.65 | 4.85 | 14.16 | -4.85 | 6.11 | +7.03 |
| 6-Jan-11 | auto | 7.17 | 6.89 | 4.11 | | | | | | | |
| 9-Jan-11 | auto | 7.19 | 6.90 | 4.16 | | | | | | | |
| 12-Jan-11 | auto | 7.20 | 6.90 | 4.29 | | | | | | | |
| 15-Jan-11 | auto | 7.23 | 6.90 | 4.80 | | | | | | | |
| 18-Jan-11 | auto | 7.30 | 6.92 | 5.54 | | | | | | | |
| 21-Jan-11 | auto | 7.33 | 6.90 | 6.25 | | | | | | | |
| 24-Jan-11 | auto | 7.41 | 6.91 | 7.31 | | | | | | | |
| 27-Jan-11 | auto | 7.43 | 6.90 | 7.67 | | | | | | | |
| 30-Jan-11 | auto | 7.47 | 6.91 | 8.18 | | | | | | | |
| 2-Feb-11 | auto | 7.53 | 6.90 | 9.07 | | | | | | | |
| 5-Feb-11 | auto | 7.54 | 6.91 | 9.18 | | | | | | | |
| 8-Feb-11 | auto | 7.55 | 6.89 | 9.55 | | | | | | | |
| 11-Feb-11 | auto | 7.62 | 6.89 | 10.58 | | | | | | | |
| 14-Feb-11 | auto | 7.58 | 6.89 | 10.05 | | | | | | | |
| 17-Feb-11 | auto | 7.67 | 6.89 | 11.32 | | | | | | | |
| 21-Feb-11 | auto | 8.91 | 9.25 | -3.68 | | | | | | | |
| 27-Feb-11 | auto | 9.01 | 9.25 | -2.59 | | | | | | | |
| 2-Mar-11 | auto | 9.05 | 9.26 | -2.27 | | | | | | | |
| 12-Mar-11 | auto | 8.01 | 8.24 | -2.71 | | | | | | | |
| 19-Mar-11 | auto | 8.12 | 8.24 | -1.36 | | | | | | | |
| 26-Mar-11 | auto | 8.19 | 8.24 | -0.56 | | | | | | | |

¹Acceptance criteria: ≤ 10%

²Acceptance criteria: ≤ ±10%

Table 2-18: 2nd Quarter CO Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 2-Apr-11 | auto | 8.2060 | 8.2350 | -0.35 | 13 | 1.36 | 2.57 | 6.40 | -3.68 | 3.55 | +3.17 |
| 9-Apr-11 | auto | 8.2710 | 8.2350 | 0.44 | | | | | | | |
| 16-Apr-11 | auto | 8.2880 | 8.2350 | 0.64 | | | | | | | |
| 23-Apr-11 | auto | 8.3340 | 8.2350 | 1.20 | | | | | | | |
| 30-Apr-11 | auto | 8.4120 | 8.2350 | 2.15 | | | | | | | |
| 7-May-11 | auto | 8.4830 | 8.2350 | 3.01 | | | | | | | |
| 14-May-11 | auto | 8.4850 | 8.2350 | 3.04 | | | | | | | |
| 21-May-11 | auto | 7.9560 | 8.2350 | -3.39 | | | | | | | |
| 28-May-11 | auto | 7.9000 | 8.2000 | -3.66 | | | | | | | |
| 4-Jun-11 | auto | 8.5000 | 8.2000 | 3.66 | | | | | | | |
| 11-Jun-11 | auto | 8.5000 | 8.2000 | 3.66 | | | | | | | |
| 18-Jun-11 | auto | 8.5000 | 8.2000 | 3.66 | | | | | | | |
| 25-Jun-11 | auto | 8.5000 | 8.2000 | 3.66 | | | | | | | |

¹Acceptance criteria: ≤ 10%

²Acceptance criteria: ≤ ±10%

Table 2-19: 3rd Quarter CO Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 2-Jul-11 | auto | 7.9000 | 8.2000 | -3.66 | 14 | -0.65 | 2.84 | 4.91 | -6.21 | 3.85 | ±3.10 |
| 9-Jul-11 | auto | 7.9000 | 8.2000 | -3.66 | | | | | | | |
| 16-Jul-11 | auto | 7.9000 | 8.2000 | -3.66 | | | | | | | |
| 23-Jul-11 | auto | 8.0000 | 8.2000 | -2.44 | | | | | | | |
| 30-Jul-11 | auto | 7.9000 | 8.2000 | -3.66 | | | | | | | |
| 6-Aug-11 | auto | 7.9000 | 8.2000 | -3.66 | | | | | | | |
| 13-Aug-11 | auto | 8.0000 | 8.2000 | -2.44 | | | | | | | |
| 23-Aug-11 | auto | 8.3000 | 8.2000 | 1.22 | | | | | | | |
| 31-Aug-11 | auto | 8.3000 | 8.2000 | 1.22 | | | | | | | |
| 3-Sep-11 | auto | 8.4000 | 8.2000 | 2.44 | | | | | | | |
| 10-Sep-11 | auto | 8.4000 | 8.2000 | 2.44 | | | | | | | |
| 17-Sep-11 | auto | 8.3000 | 8.2000 | 1.22 | | | | | | | |
| 22-Sep-11 | auto | 8.4590 | 8.2350 | 2.72 | | | | | | | |
| 29-Sep-11 | auto | 8.4660 | 8.2350 | 2.81 | | | | | | | |

¹Acceptance criteria: ≤ 10%

²Acceptance criteria: ≤ ±10%

Table 2-20: 4th Quarter CO Precision Statistics Summary

| Period | Type of Precision Check | Analyzer Response (ppm) | Precision Gas Concentration (ppm) | Percent Difference (%) | Number of Checks | Average Percent Difference | Standard Deviation | Upper 95% Limit | Lower 95% Limit | CV Upper Bound ¹ | Bias Estimate ² |
|-----------|-------------------------|-------------------------|-----------------------------------|------------------------|------------------|----------------------------|--------------------|-----------------|-----------------|-----------------------------|----------------------------|
| 6-Oct-11 | auto | 8.5 | 8.0 | 3.78 | 14 | -0.18 | 2.77 | 5.26 | -5.61 | 3.77 | ±2.97 |
| 13-Oct-11 | auto | 8.7 | 8.0 | 5.08 | | | | | | | |
| 20-Oct-11 | auto | 7.9 | 8.2 | -3.61 | | | | | | | |
| 25-Oct-11 | auto | 8.0 | 8.2 | -2.53 | | | | | | | |
| 27-Oct-11 | auto | 8.0 | 8.2 | -2.42 | | | | | | | |
| 3-Nov-11 | auto | 8.2 | 8.2 | -1.03 | | | | | | | |
| 10-Nov-11 | auto | 8.4 | 8.2 | 1.87 | | | | | | | |
| 17-Nov-11 | auto | 8.4 | 8.2 | 2.50 | | | | | | | |
| 24-Nov-11 | auto | 7.9 | 8.2 | -3.97 | | | | | | | |
| 1-Dec-11 | auto | 8.0 | 8.2 | -2.42 | | | | | | | |
| 8-Dec-11 | auto | 8.2 | 8.2 | -0.97 | | | | | | | |
| 15-Dec-11 | auto | 8.2 | 8.2 | -0.27 | | | | | | | |
| 22-Dec-11 | auto | 8.3 | 8.2 | 0.23 | | | | | | | |
| 29-Dec-11 | auto | 8.3 | 8.2 | 1.30 | | | | | | | |

¹Acceptance criteria: ≤ 10%

²Acceptance criteria: ≤ ±10%

Table 2-21: Quarterly Network PM_{2.5} Monitoring Precision Statistics

| Period | Samplers | Number of Collocated Samples | Concentration Levels | Average Percent Difference | Standard Deviation ^{1, 2} (µg/m ³) | Precision ^{1, 3} (µg/m ³) | Bias ^{1, 4} (µg/m ³) |
|--|--|------------------------------|----------------------------|----------------------------|---|--|---|
| 1 st Quarter (January 1 – March 31, 2011) | Primary FEM against Collocated FEM | 56 | ≥2 µg/m ³ | 0.2% | 0.55 | 0.27 | 0.71 |
| | | 90 | All | 7.0% | 0.62 | 0.31 | 0.74 |
| | Primary FEM against Collocated FRM | 9 | ≥2 µg/m ³ | 5.3% | 0.23 | 0.12 | 0.57 |
| | | 17 | All | -14.1% | 0.62 | 0.31 | 0.79 |
| 2 nd Quarter (April 1 – June 30, 2011) | Primary FEM against Collocated FEM | 44 | ≥2 µg/m ³ | 15.3% | 0.98 | 0.49 | 1.21 |
| | | 77 | All | -49.9% | 0.89 | 0.45 | 1.35 |
| | Primary FEM against Collocated FRM | 7 | ≥2 µg/m ³ | -9.8% | 1.41 | 0.70 | 1.64 |
| | | 12 | All | -118.4% | 1.45 | 0.72 | 1.87 |
| 3 rd Quarter (July 1 – September 30, 2011) | Primary FEM against Collocated FEM | 9 | ≥2 µg/m ³ | 20.4% | 0.69 | 0.34 | 1.21 |
| | | 71 | All | -61.2% | 0.74 | 0.37 | 1.54 |
| | Primary FEM against Collocated FRM | 5 | ≥2 µg/m ³ | -43.9% | 1.07 | 0.53 | 1.96 |
| | | 16 | All | 95.7% | 1.06 | 0.53 | 1.95 |
| 4 th Quarter (October 1 – December 31, 2011) | Primary FEM against Collocated FEM | 58 | ≥2 µg/m ³ | 4.5% | 1.67 | 0.84 | 0.96 |
| | | 85 | All | -24.1% | 1.40 | 0.70 | 0.93 |
| | Primary FEM against Collocated FRM | 10 | ≥2 µg/m ³ | -7.2% | 0.80 | 0.40 | 1.18 |
| | | 15 | All | -100.8% | 1.66 | 0.83 | 1.59 |
| Annual (January 1 – December 31, 2011) | Primary FEM against Collocated FEM | 167 | ≥2 µg/m³ | 6.7% | 1.17 | 0.59 | 0.96 |
| | | 323 | All | -29.7% | 1.01 | 0.51 | 1.11 |
| | Primary FEM against Collocated FRM | 31 | ≥2 µg/m³ | -10.0% | 1.03 | 0.51 | 1.23 |
| | | 60 | All | -27.4% | 1.22 | 0.61 | 1.52 |

¹ PM_{2.5} network precision statistics represent data from the Deadhorse monitoring station samplers.

² Standard deviation of the absolute concentration differences for the population.

³ Standard deviation of the absolute concentration difference for the population divided by 2 with a goal of ≤ 3 µg/m³ per quarter.

⁴ Average over the population of the absolute value of the individual pair concentration difference with a goal of ≤ 4 µg/m³ per quarter.

2.4.2 ANALYTICAL LABORATORY PRECISION STATISTICS

Not applicable.

2.4.3 ANALYTICAL LABORATORY PRECISION STATISTICS FOR LEAD ANALYSIS OF PARTICULATE SAMPLES

Not applicable.

2.5 ACCURACY STATISTICS

The ambient air and meteorological monitoring systems are subjected to periodic calibrations and independent quality assurance performance audits. All calibration and audit equipment are documented as traceable to authoritative standards. The purpose of these calibration and audit checks is to challenge the monitoring systems with known inputs or collocate traceable authoritative standards with them to verify that each instrument response is accurate to within established tolerances.

Table 2-22 through Table 2-30 summarize the accuracy statistics obtained during the project.

2.5.1 INSTRUMENT CALIBRATION STATISTICS

Single-point calibrations were performed on a daily basis on all gas pollutant analyzers throughout the monitoring year. The single-point calibrations consisted of challenging each instrument response with air scrubbed of all pollutants (“zero air”) and air containing a National Institute of Standards and Technology (NIST) traceable standard gas concentration equal to 80 percent of the instrument’s upper range limit (URL). If a single-point calibration zero or span drift limits are exceeded, ambient measurements are invalidated back to the most recent point in time where such measurements were known to be valid. Single-point calibration data for each parameter and parameter quality control (QC) performance statistics are provided in Appendix C.

Tables 2-22 and 2-23 summarize the quarterly quality control checks of the particulate samplers. These manual QC checks are conducted by SLR or on-site personnel and the data are transmitted to the SLR Anchorage office.

Multi-point calibrations were performed during the initialization of the monitoring year and on a biannual basis as recommended by the EPA (EPA-454/R-98-004). Additionally, multi-point calibrations were conducted under specific circumstances including: indication of analyzer malfunction, repairs or service that affected its calibration, and following significant interruptions in station operations. Multi-point calibrations consisted of challenging each instrument response with air scrubbed of all pollutants (“zero air”) and at least four concentrations spanning 80 to 90 percent of the URL. The NO₂ converter efficiency was determined following the guidelines provided in the 40 CFR 50 – Appendix F.

Table 2-22: Quality Control Checks PM_{2.5}

| Date | Ambient Temperature ¹ (°C) | | | Barometric Pressure ² (mm Hg) | | | Time (hh:mm:ss) | | | Flow Rate ³ (L/min) | | |
|---------------------------|---------------------------------------|----------|------|--|----------|------|------------------|----------|-----------|--------------------------------|----------|-------|
| | Sampler | QC Check | Diff | Sampler | QC Check | Diff | Sampler | QC Check | Diff | Sampler | QC Check | Diff |
| 31-Jan-11 | -18.8 | -19.4 | 0.6 | 752 | 752 | 0 | 13:05:00 | 13:06:00 | -00:01:00 | 16.7 | 17.21 | -3.0% |
| 18-Feb-11 | -16.2 | -16.8 | 0.6 | 754 | 758 | -4 | - | - | - | 16.7 | 16.70 | 0.0% |
| 10-Mar-11 | -22.2 | -21.7 | -0.5 | 762 | 760 | 2 | 20:30:35 | 20:29:15 | 00:01:20 | 16.7 | 16.60 | 0.6% |
| 2-Apr-11 | -26.1 | -27.8 | 1.7 | 759 | 754 | 5 | 09:33:00 | 09:31:00 | 00:02:00 | 16.7 | 16.50 | 1.2% |
| 14-Apr-11 | -19.9 | -19.8 | -0.1 | 774 | 776 | -2 | 02:08:00 | 02:10:00 | -00:02:00 | 16.7 | 16.70 | 0.0% |
| 12-May-11 | -4.9 | -4.9 | 0.0 | 771 | 771 | 0 | 13:10:00 | 13:11:00 | -00:01:00 | 16.7 | 16.70 | 0.0% |
| 30-May-11 ⁽⁴⁾ | -2.2 | -2.5 | 0.3 | 760 | 763 | -3 | 07:45:45 | 07:46:07 | -00:00:22 | 16.7 | 16.84 | -0.8% |
| 20-Jun-11 | 9.1 | 9.3 | -0.2 | 763 | 763 | 0 | 09:22:30 | 09:21:16 | 00:01:14 | 16.7 | 16.72 | -0.1% |
| 21-Jun-11 | 4.9 | 5.6 | -0.7 | 753 | 753 | 0 | 14:13:00 | 14:13:23 | -00:00:23 | 16.7 | 16.57 | 0.8% |
| 1-Jul-11 | 9.1 | 10.0 | -0.9 | 755 | 755 | 0 | 11:25:15 | 11:25:37 | -00:00:22 | 16.7 | 16.58 | 0.7% |
| 5-Jul-11 | 14.5 | 15.6 | -1.1 | 743 | 744 | -1 | 12:32:00 | 12:32:47 | -00:00:47 | 16.7 | 16.62 | 0.5% |
| 23-Jul-11 | 12.8 | 13.7 | -0.9 | 762 | 762 | 0 | 13:55:20 | 13:55:51 | -00:00:31 | 16.7 | 16.54 | 1.0% |
| 1-Aug-11 | 13.1 | 14.1 | -1.0 | 742 | 742 | 0 | 12:10:50 | 12:11:37 | -00:00:47 | 16.7 | 16.55 | 0.9% |
| 17-Aug-11 | 5.2 | 6.1 | -0.9 | 764 | 763 | 1 | 12:23:00 | 12:22:10 | 00:00:50 | 16.7 | 16.60 | 0.6% |
| 29-Aug-11 | 10.3 | 10.2 | 0.1 | 757 | 757 | 0 | 16:03:00 | 16:04:00 | -00:01:00 | 16.7 | 16.70 | 0.0% |
| 2-Sep-11 | 7.3 | 7.3 | 0.0 | 756 | 756 | 0 | 15:27:00 | 15:27:00 | 00:00:00 | 16.7 | 16.70 | 0.0% |
| 11-Sep-11 | 12.6 | 12.6 | 0.0 | 760 | 760 | 0 | 15:40:00 | 15:40:00 | 00:00:00 | 16.7 | 16.70 | 0.0% |
| 20-Sep-11 | 2.8 | 2.8 | 0.0 | 744 | 744 | 0 | 14:49:00 | 14:49:00 | 00:00:00 | 16.7 | 16.70 | 0.0% |
| 23-Sep-11 | -0.3 | -0.3 | 0.0 | 753 | 754 | -1 | 13:17:00 | 13:17:00 | 00:00:00 | 16.7 | 16.70 | 0.0% |
| 26-Sep-11 | 0.1 | 0.2 | -0.1 | 755 | 754 | 1 | 14:39:00 | 14:39:00 | 00:00:00 | 16.7 | 16.70 | 0.0% |
| 4-Oct-11 | -2.0 | -2.0 | 0.0 | 750 | 750 | 0 | 15:30:00 | 15:30:00 | 00:00:00 | 16.7 | 16.70 | 0.0% |
| 17-Oct-11 | -0.9 | -0.9 | 0.0 | 759 | 759 | 0 | 14:59:00 | 14:59:00 | 00:00:00 | 16.7 | 16.70 | 0.0% |
| 7-Nov-11 | -10.5 | -9.6 | -0.9 | 750 | 748 | 2 | 08:02:28 | 08:01:30 | 00:00:58 | 16.7 | 16.52 | 1.1% |
| 9-Nov-11 ⁽⁴⁾ | -19.3 | -18.6 | -0.7 | 747 | 747 | 2 | - | - | - | 16.7 | 16.63 | 0.4% |
| 18-Nov-11 | -26.0 | -26.0 | 0.0 | 771 | 771 | 0 | 14:51:00 | 14:53:00 | -00:02:00 | 16.7 | 16.70 | 0.0% |
| 21-Nov-11 | -31.2 | -30.0 | -1.2 | 757 | 757 | 0 | 17:11:35 | 17:12:33 | -00:00:58 | 16.7 | 16.70 | 0.0% |
| 28-Nov-11 | -27.5 | -27.5 | 0.0 | 756 | 756 | 0 | 13:03:02 | 13:04:13 | -00:01:11 | 16.7 | 16.70 | 0.0% |
| 19-Dec-11 | -29.7 | -29.6 | -0.1 | 747 | 747 | 0 | 16:43:00 | 16:44:00 | -00:01:00 | 16.7 | 16.70 | 0.0% |
| Average Difference | -0.2 | | | 0.1 | | | -00:00:16 | | | 0.14 | | |
| Standard Deviation | 0.6 | | | 1.6 | | | 00:00:58 | | | 0.77 | | |

¹ Acceptable criteria ±2°C

² Acceptable criteria ±10 mmHg

³ Acceptable criteria ±4% of reference

⁴ Multi-point calibration performed

Table 2-23: Quality Control Checks PM₁₀

| Date | Ambient Temperature ¹ (°C) | | | Barometric Pressure ² (mmHg) | | | Time (hh:mm:ss) | | | Flow Rate ³ (L/min) | | |
|---------------------------|---------------------------------------|----------|------|---|----------|------|-----------------|----------|-----------|--------------------------------|----------|-------|
| | Sampler | QC Check | Diff | Sampler | QC Check | Diff | Sampler | QC Check | Diff | Sampler | QC Check | Diff |
| 18-Feb-11 ⁽⁴⁾ | - | - | - | - | - | - | - | - | - | 16.7 | 16.70 | 0.0% |
| 10-Mar-11 ⁽⁵⁾ | -22.2 | -21.4 | -0.8 | 762 | 757 | 5 | 17:27:00 | 17:27:00 | 00:00:00 | 16.7 | 17.00 | -1.8% |
| 2-Apr-11 | -27.5 | -27.8 | 0.3 | 758 | 755 | 3 | 08:33:00 | 08:31:00 | 00:02:00 | 16.7 | 16.50 | 1.2% |
| 6-May-11 | -11.4 | -11.4 | 0.0 | 751 | 750 | 1 | 02:04:00 | 02:05:00 | -00:01:00 | 16.7 | 16.70 | 0.0% |
| 30-May-11 ⁽⁵⁾ | 0.3 | 0.0 | 0.3 | 760 | 763 | -3 | - | - | - | 16.7 | 16.48 | 1.3% |
| 20-Jun-11 | 9.1 | 9.4 | -0.3 | 763 | 763 | 0 | 09:24:30 | 09:24:42 | -00:00:12 | 16.7 | 16.74 | -0.2% |
| 21-Jun-11 | 5.2 | 5.6 | -0.4 | 753 | 753 | 0 | 14:15:20 | 14:15:08 | 00:00:12 | 16.7 | 16.79 | -0.5% |
| 1-Jul-11 | 9.7 | 10.0 | -0.3 | 755 | 755 | 0 | 11:21:30 | 11:21:37 | -00:00:07 | 16.7 | 16.81 | -0.7% |
| 5-Jul-11 | 15.9 | 15.6 | 0.3 | 744 | 744 | 0 | 12:35:40 | 12:36:27 | -00:00:47 | 16.7 | 16.89 | -1.1% |
| 23-Jul-11 | 13.9 | 13.7 | 0.2 | 762 | 762 | 0 | 13:52:23 | 13:52:50 | -00:00:27 | 16.7 | 16.78 | -0.5% |
| 1-Aug-11 | 14.7 | 14.1 | 0.6 | 742 | 742 | 0 | 12:12:15 | 12:13:28 | -00:01:13 | 16.7 | 16.90 | -1.2% |
| 17-Aug-11 | 5.5 | 5.7 | -0.2 | 763 | 763 | 0 | 12:28:00 | 12:25:59 | 00:02:01 | 16.7 | 16.68 | 0.1% |
| 29-Aug-11 | 10.3 | 10.3 | 0.0 | 758 | 758 | 0 | 16:06:00 | 16:06:00 | 00:00:00 | 16.7 | 16.70 | 0.0% |
| 2-Sep-11 | 7.2 | 7.2 | 0.0 | 755 | 755 | 0 | 15:17:00 | 15:18:00 | -00:01:00 | 16.7 | 16.70 | 0.0% |
| 11-Sep-11 | 12.9 | 12.9 | 0.0 | 758 | 758 | 0 | 15:33:00 | 15:34:00 | -00:01:00 | 16.7 | 16.70 | 0.0% |
| 20-Sep-11 | 2.8 | 2.8 | 0.0 | 743 | 743 | 0 | 14:50:00 | 14:50:00 | 00:00:00 | 16.7 | 16.70 | 0.0% |
| 23-Sep-11 | -0.5 | -0.5 | 0.0 | 753 | 753 | 0 | 13:11:00 | 13:11:00 | 00:00:00 | 16.7 | 16.70 | 0.0% |
| 26-Sep-11 | 0.3 | 0.3 | 0.0 | 754 | 754 | 0 | 14:34:00 | 14:34:00 | 00:00:00 | 16.7 | 16.70 | 0.0% |
| 4-Oct-11 | -1.8 | -1.8 | 0.0 | 750 | 750 | 0 | 15:28:00 | 15:29:00 | -00:01:00 | 16.7 | 16.70 | 0.0% |
| 17-Oct-11 | 0.9 | 0.9 | 0.0 | 758 | 758 | 0 | 14:57:00 | 14:57:00 | 00:00:00 | 16.7 | 16.70 | 0.0% |
| 7-Nov-11 | -10.5 | -9.5 | -1.0 | 750 | 748 | 2 | 08:02:02 | 08:02:30 | -00:00:28 | 16.7 | 16.67 | 0.2% |
| 9-Nov-11 ⁽⁴⁾ | -19.4 | -18.6 | -1.2 | 749 | 747 | 2 | - | - | - | 16.7 | 16.72 | -0.1% |
| 18-Nov-11 | -26.0 | -26.0 | 0.0 | 771 | 770 | 1 | 15:05:00 | 15:06:00 | -00:01:00 | 16.7 | 16.70 | 0.0% |
| 21-Nov-11 | -31.6 | -31.6 | 0.0 | 758 | 758 | 0 | 17:11:35 | 17:12:33 | -00:00:58 | 16.7 | 16.70 | 0.0% |
| 28-Nov-11 | -27.2 | -27.1 | -0.1 | 756 | 755 | 1 | 12:55:03 | 12:56:33 | -00:01:30 | 16.7 | 16.70 | 0.0% |
| 19-Dec-11 | -29.9 | -29.9 | 0.0 | 748 | 749 | -1 | 16:56:00 | 16:57:00 | -00:01:00 | 16.7 | 16.70 | 0.0% |
| Average Difference | -0.1 | | | 0.4 | | | -00:00:20 | | | -0.13 | | |
| Standard Deviation | 0.4 | | | 1.4 | | | 00:00:53 | | | 0.62 | | |

¹ Acceptable criteria ±2°C

² Acceptable criteria ±10 mmHg

³ Acceptable criteria ±4% of reference

⁴ Calibration of TEOM PM₁₀ sampler

⁵ Multi-point calibration performed

Table 2-24: Calibration Summary – SO₂

| Period | Calibration Gas Concentration (ppm) | Analyzer Response (ppm) | Percent Difference (%) | Mean Absolute Percent Difference (%) | Slope | Y-Intercept | R ² | Pass/Fail ¹ |
|-------------------|-------------------------------------|-------------------------|------------------------|--------------------------------------|--------|-------------|----------------|------------------------|
| February 17, 2011 | 0.0000 | -0.0004 | - | 1.9 | 1.0304 | -0.0016 | 0.9999 | Pass |
| | 0.0884 | 0.0891 | 0.8 | | | | | |
| | 0.1665 | 0.1669 | 0.2 | | | | | |
| | 0.2448 | 0.2520 | 2.9 | | | | | |
| | 0.3903 | 0.4040 | 3.5 | | | | | |
| | 0.4408 | 0.4500 | 2.1 | | | | | |
| March 10, 2011 | 0.0000 | -0.0005 | - | 1.4 | 1.0138 | 0.0001 | 0.9999 | Pass |
| | 0.0785 | 0.0791 | 0.8 | | | | | |
| | 0.1715 | 0.1737 | 1.3 | | | | | |
| | 0.2935 | 0.3007 | 2.5 | | | | | |
| | 0.3916 | 0.3997 | 2.1 | | | | | |
| | 0.4402 | 0.4424 | 0.5 | | | | | |
| May 30, 2011 | 0.0000 | 0.0002 | - | 0.5 | 1.0012 | 0.0007 | 0.99995 | Pass |
| | 0.0782 | 0.0789 | 0.9 | | | | | |
| | 0.1711 | 0.1714 | 0.1 | | | | | |
| | 0.2935 | 0.2982 | 1.6 | | | | | |
| | 0.3914 | 0.3917 | 0.1 | | | | | |
| | 0.4403 | 0.4403 | 0.0 | | | | | |
| June 28, 2011 | 0.0008 | 0.0008 | - | 0.5 | 0.9971 | 0.0005 | 0.99996 | Pass |
| | 0.0787 | 0.0792 | 0.7 | | | | | |
| | 0.1712 | 0.1720 | 0.5 | | | | | |
| | 0.2944 | 0.2910 | -1.1 | | | | | |
| | 0.3911 | 0.3910 | 0.0 | | | | | |
| | 0.4405 | 0.4410 | 0.1 | | | | | |

Table 2-24 Continued: Calibration Summary – SO₂

| Period | Calibration Gas Concentration (ppm) | Analyzer Response (ppm) | Percent Difference (%) | Mean Absolute Percent Difference (%) | Slope | Y-Intercept | R ² | Pass/Fail ¹ |
|------------------|-------------------------------------|-------------------------|------------------------|--------------------------------------|--------|-------------|----------------|------------------------|
| August 18, 2011 | 0.0000 | 0.0003 | - | 0.8 | 1.0047 | 0.0005 | 0.99993 | Pass |
| | 0.0791 | 0.0790 | -0.1 | | | | | |
| | 0.1725 | 0.1746 | 1.2 | | | | | |
| | 0.2953 | 0.3000 | 1.6 | | | | | |
| | 0.3943 | 0.3932 | -0.3 | | | | | |
| | 0.4433 | 0.4470 | 0.8 | | | | | |
| November 8, 2011 | 0.0000 | 0.0003 | - | 1.0 | 1.0056 | -0.0009 | 0.99993 | Pass |
| | 0.0789 | 0.0779 | -1.3 | | | | | |
| | 0.1725 | 0.1696 | -1.7 | | | | | |
| | 0.2957 | 0.2995 | 1.3 | | | | | |
| | 0.3940 | 0.3963 | 0.6 | | | | | |
| | 0.4435 | 0.4435 | 0.0 | | | | | |

¹Acceptance criteria:

1. Measured and audit point difference ≤ ±15%
2. Slope ≥ 0.9 and ≤ 1.10
3. R² ≥ 0.9950
4. Y-intercept ≤ ±3% of full scale

Table 2-25: Calibration Summary – CO

| Period | Calibration Gas Concentration (ppm) | Analyzer Response (ppm) | Percent Difference (%) | Mean Absolute Percent Difference (%) | Slope | Y-Intercept | R ² | Pass/Fail ¹ |
|-------------------|-------------------------------------|-------------------------|------------------------|--------------------------------------|--------|-------------|----------------|------------------------|
| February 17, 2011 | 0.0 | 0.0 | - | 1.0 | 1.0113 | -0.0515 | 0.99997 | Pass |
| | 9.0 | 8.9 | -0.9 | | | | | |
| | 16.9 | 17.0 | 0.5 | | | | | |
| | 24.8 | 25.2 | 1.5 | | | | | |
| | 39.6 | 40.1 | 1.3 | | | | | |
| | 44.7 | 45.0 | 0.7 | | | | | |
| March 10, 2011 | 0.000 | 0.494 | - | 5.5 | 1.0305 | 0.5010 | 0.99995 | Pass |
| | 7.959 | 8.611 | 8.2 | | | | | |
| | 17.388 | 18.370 | 5.6 | | | | | |
| | 29.757 | 31.500 | 5.9 | | | | | |
| | 39.712 | 41.423 | 4.3 | | | | | |
| | 44.639 | 46.310 | 3.7 | | | | | |
| May 30, 2011 | 0.0 | 0.1 | - | 1.0 | 0.9996 | -0.0545 | 0.99979 | Pass |
| | 8.0 | 7.9 | -1.2 | | | | | |
| | 17.5 | 17.3 | -1.0 | | | | | |
| | 30.0 | 30.0 | 0.0 | | | | | |
| | 39.9 | 39.3 | -1.6 | | | | | |
| | 43.6 | 44.1 | 1.1 | | | | | |
| June 28, 2011 | 0.0 | 0.0 | - | 0.3 | 0.9973 | 0.0496 | 0.99997 | Pass |
| | 8.0 | 8.0 | 0.2 | | | | | |
| | 17.4 | 17.4 | 0.0 | | | | | |
| | 29.9 | 30.0 | 0.5 | | | | | |
| | 39.7 | 39.7 | 0.1 | | | | | |
| | 44.7 | 44.4 | -0.6 | | | | | |

Table 2-25 Continued: Calibration Summary – CO

| Period | Calibration Gas Concentration (ppm) | Analyzer Response (ppm) | Percent Difference (%) | Mean Absolute Percent Difference (%) | Slope | Y-Intercept | R ² | Pass/Fail ¹ |
|------------------|-------------------------------------|-------------------------|------------------------|--------------------------------------|--------|-------------|----------------|------------------------|
| August 18, 2011 | 0.0 | 0.1 | - | 1.1 | 1.0033 | 0.1564 | 0.99996 | Pass |
| | 8.0 | 8.2 | 1.8 | | | | | |
| | 17.5 | 17.7 | 1.1 | | | | | |
| | 30.0 | 30.4 | 1.6 | | | | | |
| | 39.9 | 40.3 | 1.0 | | | | | |
| | 44.9 | 45.0 | 0.2 | | | | | |
| November 8, 2011 | 0.0 | 0.3 | - | 2.3 | 1.0052 | 0.3562 | 0.99993 | Pass |
| | 8.0 | 8.3 | 4.0 | | | | | |
| | 17.5 | 17.9 | 2.5 | | | | | |
| | 30.0 | 30.9 | 3.0 | | | | | |
| | 40.0 | 40.6 | 1.5 | | | | | |
| | 44.9 | 45.3 | 0.7 | | | | | |

¹Acceptance criteria:

1. Measured and audit point difference ≤ ±15%
2. Slope ≥ 0.9 and ≤ 1.10
3. R² ≥ 0.9950
4. Y-intercept ≤ ±3% of full scale

Table 2-26: Calibration Summary – O₃

| Period | Calibration Gas Concentration (ppm) | Analyzer Response (ppm) | Percent Difference (%) | Mean Absolute Percent Difference (%) | Slope | Y-Intercept | R ² | Pass/Fail ¹ |
|-------------------|-------------------------------------|-------------------------|------------------------|--------------------------------------|--------|-------------|----------------|------------------------|
| February 17, 2011 | -0.001 | 0.000 | - | 1.2 | 1.0068 | 0.0012 | 1.00000 | Pass |
| | 0.080 | 0.081 | 1.8 | | | | | |
| | 0.175 | 0.178 | 1.4 | | | | | |
| | 0.300 | 0.304 | 1.2 | | | | | |
| | 0.400 | 0.404 | 0.9 | | | | | |
| | 0.450 | 0.454 | 0.9 | | | | | |
| March 10, 2011 | 0.001 | 0.001 | - | 2.2 | 0.9979 | -0.0026 | 0.99995 | Pass |
| | 0.080 | 0.076 | -5.6 | | | | | |
| | 0.175 | 0.170 | -2.7 | | | | | |
| | 0.300 | 0.297 | -1.2 | | | | | |
| | 0.400 | 0.397 | -0.8 | | | | | |
| | 0.451 | 0.448 | -0.8 | | | | | |
| April 1, 2011 | 0.000 | 0.000 | - | 1.9 | 1.0100 | 0.0013 | 0.99999 | Pass |
| | 0.080 | 0.083 | 3.8 | | | | | |
| | 0.175 | 0.179 | 2.1 | | | | | |
| | 0.301 | 0.305 | 1.4 | | | | | |
| | 0.401 | 0.406 | 1.3 | | | | | |
| | 0.451 | 0.456 | 1.2 | | | | | |
| May 30, 2011 | 0.000 | 0.000 | - | 2.0 | 1.0326 | -0.0044 | 1.00000 | Pass |
| | 0.080 | 0.083 | 3.2 | | | | | |
| | 0.175 | 0.179 | 2.2 | | | | | |
| | 0.300 | 0.305 | 1.6 | | | | | |
| | 0.400 | 0.406 | 1.4 | | | | | |
| | 0.451 | 0.457 | 1.3 | | | | | |

Table 2-26 Continued: Calibration Summary – O₃

| Period | Calibration Gas Concentration (ppm) | Analyzer Response (ppm) | Percent Difference (%) | Mean Absolute Percent Difference (%) | Slope | Y-Intercept | R ² | Pass/Fail ¹ |
|------------------|-------------------------------------|-------------------------|------------------------|--------------------------------------|--------|-------------|----------------|------------------------|
| June 19, 2011 | 0.000 | 0.000 | - | 1.4 | 0.9990 | 0.0022 | 0.99992 | Pass |
| | 0.082 | 0.084 | 2.8 | | | | | |
| | 0.179 | 0.182 | 1.6 | | | | | |
| | 0.300 | 0.304 | 1.5 | | | | | |
| | 0.395 | 0.399 | 0.9 | | | | | |
| | 0.450 | 0.448 | -0.4 | | | | | |
| August 18, 2011 | 0.000 | 0.000 | - | 1.6 | 1.0129 | 0.0003 | 1.00000 | Pass |
| | 0.080 | 0.082 | 2.6 | | | | | |
| | 0.175 | 0.177 | 1.2 | | | | | |
| | 0.300 | 0.304 | 1.2 | | | | | |
| | 0.400 | 0.406 | 1.4 | | | | | |
| | 0.451 | 0.457 | 1.4 | | | | | |
| October 4, 2011 | -0.001 | 0.009 | - | 2.4 | 0.9981 | 0.0066 | 0.99993 | Pass |
| | 0.080 | 0.084 | 4.5 | | | | | |
| | 0.175 | 0.180 | 2.8 | | | | | |
| | 0.300 | 0.305 | 1.8 | | | | | |
| | 0.400 | 0.407 | 1.7 | | | | | |
| | 0.450 | 0.457 | 1.5 | | | | | |
| November 8, 2011 | 0.001 | -0.004 | - | 0.5 | 1.0026 | -0.0024 | 0.99997 | Pass |
| | 0.081 | 0.080 | -1.0 | | | | | |
| | 0.175 | 0.175 | -0.2 | | | | | |
| | 0.301 | 0.300 | -0.3 | | | | | |
| | 0.401 | 0.399 | -0.5 | | | | | |
| | 0.450 | 0.448 | -0.4 | | | | | |

¹Acceptance criteria:

1. Measured and audit point difference ≤ ±10%
2. Slope ≥ 0.9 and ≤ 1.10
3. R² ≥ 0.9950
4. Y-intercept ≤ ±3% of full scale

Table 2-27: Calibration Summary – NO₂

| Period | Calibration Gas Concentration (ppm) | Analyzer Response (ppm) | Percent Difference (%) | Mean Absolute Percent Difference (%) | Slope | Y-Intercept | R ² | Converter Efficiency | Pass/Fail ¹ |
|-------------------|-------------------------------------|-------------------------|------------------------|--------------------------------------|--------|-------------|----------------|----------------------|------------------------|
| February 17, 2011 | 0.000 | 0.001 | - | 0.9 | 0.9995 | 0.0016 | 0.99999 | 99.1% | Pass |
| | 0.082 | 0.084 | 2.2 | | | | | | |
| | 0.169 | 0.171 | 1.1 | | | | | | |
| | 0.296 | 0.297 | 0.4 | | | | | | |
| | 0.349 | 0.352 | 0.8 | | | | | | |
| | 0.394 | 0.394 | 0.1 | | | | | | |
| March 10, 2011 | 0.000 | -0.001 | - | 2.9 | 1.0318 | -0.0008 | 0.99997 | 99.9% | Pass |
| | 0.089 | 0.091 | 2.4 | | | | | | |
| | 0.177 | 0.184 | 3.6 | | | | | | |
| | 0.306 | 0.314 | 2.3 | | | | | | |
| | 0.401 | 0.412 | 2.7 | | | | | | |
| | 0.418 | 0.432 | 3.4 | | | | | | |
| April 28, 2011 | 0.000 | 0.000 | - | 1.1 | 1.0021 | 0.0010 | 0.99997 | 99.4% | Pass |
| | 0.084 | 0.087 | 4.1 | | | | | | |
| | 0.176 | 0.177 | 0.3 | | | | | | |
| | 0.300 | 0.301 | 0.3 | | | | | | |
| | 0.383 | 0.384 | 0.4 | | | | | | |
| | 0.414 | 0.417 | 0.7 | | | | | | |
| May 30, 2011 | 0.000 | 0.000 | - | 0.9 | 1.0065 | 0.0002 | 0.99999 | 99.7% | Pass |
| | 0.088 | 0.089 | 2.1 | | | | | | |
| | 0.179 | 0.179 | 0.0 | | | | | | |
| | 0.309 | 0.311 | 0.8 | | | | | | |
| | 0.391 | 0.394 | 0.7 | | | | | | |
| | 0.425 | 0.428 | 0.7 | | | | | | |

Table 2-27 Continued: Calibration Summary – NO₂

| Period | Calibration Gas Concentration (ppm) | Analyzer Response (ppm) | Percent Difference (%) | Mean Absolute Percent Difference (%) | Slope | Y-Intercept | R ² | Converter Efficiency | Pass/Fail ¹ |
|------------------|-------------------------------------|-------------------------|------------------------|--------------------------------------|--------|-------------|----------------|----------------------|------------------------|
| August 18, 2011 | 0.000 | 0.000 | - | 1.3 | 0.9854 | 0.0009 | 0.99998 | 99.5% | Pass |
| | 0.069 | 0.071 | 1.9 | | | | | | |
| | 0.151 | 0.149 | -1.0 | | | | | | |
| | 0.266 | 0.262 | -1.2 | | | | | | |
| | 0.337 | 0.333 | -1.3 | | | | | | |
| | 0.366 | 0.362 | -1.1 | | | | | | |
| November 8, 2011 | 0.000 | 0.000 | - | 3.8 | 1.0355 | 0.0003 | 1.00000 | 100.2% | Pass |
| | 0.076 | 0.079 | 4.0 | | | | | | |
| | 0.165 | 0.171 | 3.9 | | | | | | |
| | 0.291 | 0.302 | 3.7 | | | | | | |
| | 0.376 | 0.390 | 3.6 | | | | | | |
| | 0.404 | 0.419 | 3.7 | | | | | | |

¹Acceptance criteria:

1. Measured and audit point difference $\leq \pm 15\%$
2. Slope ≥ 0.9 and ≤ 1.10
3. $R^2 \geq 0.9950$
4. Y-intercept $\leq \pm 3\%$ of full scale
5. Converter efficiency $\geq 96.0\%$

Table 2-28: March 5, 2011 Meteorological Calibration Summary

| Parameter | Limit | Units | Max Error | Status |
|---|--|-----------------------|-----------|--------|
| Low Wind Speed Accuracy (≤ 5 m/s) | $\leq \pm 0.20$ | m/s | 0.00 | Pass |
| High Wind Speed Accuracy (> 5 m/s) | ≤ 5 | % input | 0.00 | Pass |
| Wind Speed Torque | ≤ 1.0 | gm-cm | 0.30 | Pass |
| Wind Direction Accuracy | $\leq \pm 5$ | Degree | 1.4 | Pass |
| Wind Direction Linearity | $\leq \pm 3$ | Degree | 0.8 | Pass |
| Wind Direction Torque | ≤ 11 | gm-cm | 6.0 | Pass |
| Vertical Wind Speed Accuracy | $\leq \pm 0.20 \pm 5\%$ known input | m/s | 0.34 | Pass |
| Vertical Wind Speed Torque | ≤ 0.30 | gm-cm | 0.30/0.20 | Pass |
| Solar Radiation Accuracy | $\leq \pm 10$ | mean W/m ² | 4.9 | Pass |

Table 2-29: May 29, 2011 Meteorological Calibration Summary

| Parameter | Limit | Units | Max Error | Status |
|---|--|--------------------|-----------|--------|
| Time | $\leq \pm 5$ | mm:ss | 03:02 | Pass |
| 2-m Temperature Accuracy | $\leq \pm 0.50$ | $^{\circ}\text{C}$ | 0.10 | Pass |
| 10-m Temperature Accuracy | $\leq \pm 0.50$ | $^{\circ}\text{C}$ | 0.10 | Pass |
| Air Temperature Difference | $\leq \pm 0.10$ | $^{\circ}\text{C}$ | 0.02 | Pass |
| Low Wind Speed Accuracy (≤ 5 m/s) | $\leq \pm 0.20$ | m/s | 0.00 | Pass |
| High Wind Speed Accuracy (> 5 m/s) | ≤ 5 | % input | 0.00 | Pass |
| Wind Speed Torque | ≤ 1.0 | gm-cm | 0.10 | Pass |
| Wind Direction Alignment | $\leq \pm 5$ | Degree | 3.0 | Pass |
| Wind Direction Linearity | $\leq \pm 3$ | Degree | 0.9 | Pass |
| Wind Direction Torque | ≤ 11 | gm-cm | 5.0 | Pass |
| Vertical Wind Speed Accuracy | $\leq \pm 0.20 \pm 5\%$ known input | m/s | 0.8 | Pass |
| Vertical Wind Speed Torque | ≤ 0.20 | gm-cm | 0.15 | Pass |
| Solar Radiation Accuracy | $\leq \pm 5$ | % input | 3.1 | Pass |

Table 2-30: November 7, 2011 Meteorological Calibration Summary

| Parameter | Limit | Units | Max Error | Status |
|---|--|--------------------|-----------|--------|
| Time | $\leq \pm 5$ | mm:ss | 00:02 | Pass |
| 2-m Temperature Accuracy | $\leq \pm 0.50$ | $^{\circ}\text{C}$ | 0.06 | Pass |
| 10-m Temperature Accuracy | $\leq \pm 0.50$ | $^{\circ}\text{C}$ | 0.12 | Pass |
| Air Temperature Difference | $\leq \pm 0.10$ | $^{\circ}\text{C}$ | 0.09 | Pass |
| Low Wind Speed Accuracy (≤ 5 m/s) | $\leq \pm 0.20$ | m/s | 0.10 | Pass |
| High Wind Speed Accuracy (> 5 m/s) | ≤ 5 | % input | 0.00 | Pass |
| Wind Speed Torque | ≤ 1.0 | gm-cm | 0.10 | Pass |
| Wind Direction Alignment | $\leq \pm 5$ | Degree | 4.0 | Pass |
| Wind Direction Linearity | $\leq \pm 3$ | Degree | 1.8 | Pass |
| Wind Direction Torque | ≤ 11 | gm-cm | 4.0 | Pass |
| Vertical Wind Speed Accuracy | $\leq \pm 0.20 \pm 5\%$ known input | m/s | 0.40 | Pass |
| Vertical Wind Speed Torque | ≤ 0.31 | gm-cm | 0.10 | Pass |
| Solar Radiation Accuracy | $\leq \pm 10$ | W/m^2 | 0.3 | Pass |

2.5.2 INDEPENDENT QUALITY ASSURANCE AUDITS

Gas analyzer performance audits involve challenging the analyzer with known concentrations of pollutants. For each concentration challenge, the difference between the audit gas concentration and analyzer response is assessed and compared to PSD limits. Results of the gas analyzer audits conducted during the monitoring year are presented in Tables 2-31 to 2-34.

The gas analyzers performance audit acceptance criterion for an individual analyzer is that the mean absolute difference between the audit gas concentration and analyzer response is equal to or less than 15 percent for CO, SO₂, NO, NO_x, and NO₂ and equal to or less than 10 percent for O₃. Linear regression acceptance criteria of the best-fit line of individual pollutant parameter audit points are: a) the slope is greater than or equal to 0.85 and less than or equal to 1.15, b) the y-intercept is less than or equal to 3 percent of the full scale of the analyzer, and c) the R-squared value is greater than or equal to 0.995.

The performance audits of PM_{2.5} and PM₁₀ samplers challenge the flow rate of the monitors against independent instruments that are calibrated and traceable to National Institute of Standards and Technology (NIST) transfer standards. Audits of the PM_{2.5} and PM₁₀ are conducted using an audit orifice transfer standard (BGI Delta Cal or equivalent).

Meteorological performance audits involve challenging the sensors with known inputs or by using calibrated instruments collocated with the sensor. For each reading, the difference between the station value and the expected value is compared with established PSD limits to assess the accuracy of the sensor. Results of the meteorological audits conducted throughout the monitoring year are presented in Tables 2-37 to 2-38.

AMS Tech LLC. completed performance audits on all station monitors. All meteorological sensors and gaseous analyzers were found to be operating within acceptable criteria throughout the monitoring year. Complete performance audit findings and details are provided in Appendix C.

In order to meet the 40 CFR Part 58, Appendix A, Section 3.2.7, the Deadhorse station is within a network "Performance Evaluation Program (PEP)-like" audits program performed by an independent auditor. During the 2011 monitoring year this audit occurred at the Wainwright monitoring station. This "PEP-like" audit is designed to satisfy the intent of the requirements to obtain an independent assessment of system bias and is a comparable program to that of the PEP audit program. Results of the PEP audit at Wainwright station are summarized in Table 2-39 and the full audit report is available in Appendix C.

EPA recommends that a technical systems audit (TSA) be conducted to serve as a qualitative review of all aspects of a monitoring program. The systems audit includes a review of the program plan, station site, facilities, equipment, personnel, procedures, record keeping, data validation and data reporting. An annual TSA was performed in December 2011 at the Nuiqsut monitoring station. The audit indicated that the monitoring project is staffed with experienced personnel with a defined organization, and that the station is well-planned and properly sited according to criteria recommended by the EPA. Appendix C contains the complete technical systems audit report.

Table 2-31: Performance Audit Summary – SO₂

| Period | Audit Point | Audit Gas Concentration (ppb) | Analyzer Response (ppb) | Percent Difference (%) | Mean Absolute Percent Difference (%) | Linear Regression Statistics | | | Pass/Fail ¹ |
|------------------|-------------|-------------------------------|-------------------------|------------------------|--------------------------------------|------------------------------|-------------|----------------|------------------------|
| | | | | | | Slope | Y-Intercept | R ² | |
| March 16, 2011 | 0 | 0 | 0 | - | 2.7 | 0.9860 | -1.175 | 1.0000 | Pass |
| | 1 | 71 | 68 | -4.2 | | | | | |
| | 2 | 210 | 205 | -2.4 | | | | | |
| | 3 | 454 | 447 | -1.5 | | | | | |
| June 2, 2011 | 0 | 0 | -1 | - | 3.0 | 0.9801 | -1.349 | 1.0000 | Pass |
| | 1 | 76 | 73 | -3.9 | | | | | |
| | 2 | 211 | 205 | -2.8 | | | | | |
| | 3 | 446 | 436 | -2.2 | | | | | |
| August 18, 2011 | 0 | 0 | -2 | - | 9.2 | 0.9523 | -4.496 | 0.9999 | Pass |
| | 1 | 80 | 69 | -13.8 | | | | | |
| | 2 | 148 | 136 | -8.1 | | | | | |
| | 3 | 443 | 418 | -5.6 | | | | | |
| November 7, 2011 | 0 | 0 | 0 | - | 1.4 | 0.9883 | -0.271 | 1.0000 | Pass |
| | 1 | 73 | 72 | -1.4 | | | | | |
| | 2 | 245 | 241 | -1.6 | | | | | |
| | 3 | 441 | 436 | -1.1 | | | | | |

¹Acceptance criteria:

1. Measured and audit point difference $\leq \pm 15\%$
2. Slope ≥ 0.9 and ≤ 1.10
3. $R^2 \geq 0.9950$
4. Y-intercept $\leq \pm 3\%$ of full scale

Table 2-32: Performance Audit Summary – CO

| Period | Audit Point | Audit Gas Concentration (ppm) | Analyzer Response (ppm) | Percent Difference (%) | Mean Absolute Percent Difference (%) | Linear Regression Statistics | | | Pass/Fail ¹ |
|------------------|-------------|-------------------------------|-------------------------|------------------------|--------------------------------------|------------------------------|-------------|----------------|------------------------|
| | | | | | | Slope | Y-Intercept | R ² | |
| March 16, 2011 | 0 | 0.00 | 0.02 | - | 0.28 | 1.0339 | -0.069 | 1.0000 | Pass |
| | 1 | 2.00 | 2.00 | 0.0 | | | | | |
| | 2 | 5.90 | 5.92 | 0.3 | | | | | |
| | 3 | 33.03 | 34.10 | 3.2 | | | | | |
| June 2, 2011 | 0 | 0.00 | 0.55 | - | 4.3 | 1.0092 | 0.324 | 0.9999 | Pass |
| | 1 | 2.53 | 2.68 | 5.9 | | | | | |
| | 2 | 6.60 | 6.93 | 5.0 | | | | | |
| | 3 | 32.70 | 33.35 | 2.0 | | | | | |
| August 18, 2011 | 0 | 0.00 | 0.19 | - | 2.3 | 1.0112 | 0.111 | 1.0000 | Pass |
| | 1 | 2.23 | 2.31 | 3.6 | | | | | |
| | 2 | 12.45 | 12.65 | 1.6 | | | | | |
| | 3 | 27.78 | 28.23 | 1.6 | | | | | |
| November 7, 2011 | 0 | 0.00 | 0.29 | - | 7.5 | 1.0508 | 0.184 | 1.0000 | Pass |
| | 1 | 2.04 | 2.25 | 10.3 | | | | | |
| | 2 | 12.09 | 12.80 | 5.9 | | | | | |
| | 3 | 21.47 | 22.80 | 6.2 | | | | | |

¹Acceptance criteria:

1. Measured and audit point difference $\leq \pm 15\%$
2. Slope ≥ 0.9 and ≤ 1.10
3. $R^2 \geq 0.9950$
4. Y-intercept $\leq \pm 3\%$ of full scale

Table 2-33: Performance Audit Summary – O₃

| Period | Audit Point | Audit Gas Concentration (ppb) | Analyzer Response (ppb) | Percent Difference (%) | Mean Absolute Percent Difference (%) | Linear Regression Statistics | | | Pass/Fail ¹ |
|------------------|-------------|-------------------------------|-------------------------|------------------------|--------------------------------------|------------------------------|-------------|----------------|------------------------|
| | | | | | | Slope | Y-Intercept | R ² | |
| March 16, 2011 | 0 | 0 | 1 | - | 2.4 | 0.9838 | -0.779 | 1.0000 | Pass |
| | 1 | 70 | 68 | -2.9 | | | | | |
| | 2 | 133 | 129 | -3.0 | | | | | |
| | 3 | 212 | 206 | -2.8 | | | | | |
| | 4 | 455 | 448 | -1.5 | | | | | |
| June 3, 2011 | 0 | 0 | 2 | - | 1.6 | 0.9903 | 0.081 | 1.0000 | Pass |
| | 1 | 71 | 69 | -2.8 | | | | | |
| | 2 | 152 | 150 | -1.3 | | | | | |
| | 3 | 231 | 228 | -1.3 | | | | | |
| | 4 | 415 | 412 | -0.7 | | | | | |
| August 18, 2011 | 0 | 0 | 0 | - | 1.7 | 0.9899 | -0.708 | 1.0000 | Pass |
| | 1 | 86 | 84 | -2.3 | | | | | |
| | 2 | 145 | 143 | -1.4 | | | | | |
| | 3 | 231 | 227 | -1.7 | | | | | |
| | 4 | 472 | 467 | -1.1 | | | | | |
| November 7, 2011 | 0 | 0 | -1 | - | 1.3 | 0.9985 | -1.527 | 1.0000 | Pass |
| | 1 | 76 | 74 | -2.6 | | | | | |
| | 2 | 147 | 145 | -1.4 | | | | | |
| | 3 | 253 | 251 | -0.8 | | | | | |
| | 4 | 463 | 461 | -0.4 | | | | | |

¹Acceptance criteria:

1. Measured and audit point difference $\leq \pm 10\%$
2. Slope ≥ 0.9 and ≤ 1.10
3. R² ≥ 0.9950
4. Y-intercept $\leq \pm 3\%$ of full scale

Table 2-34: Performance Audit Summary – NO₂

| Period | Audit Point | Audit Gas Concentration (ppb) | Analyzer Response (ppb) | Percent Difference (%) | Mean Absolute Percent Difference (%) | Linear Regression Statistics | | | Converter Efficiency | Pass/Fail ¹ |
|------------------|-------------|-------------------------------|-------------------------|------------------------|--------------------------------------|------------------------------|-------------|----------------|----------------------|------------------------|
| | | | | | | Slope | Y-Intercept | R ² | | |
| March 16, 2011 | 0 | 0 | -1 | - | 1.3 | 1.0243 | -2.218 | 1.0000 | 100.0% | Pass |
| | 1 | 69 | 68 | -1.4 | | | | | | |
| | 2 | 195 | 196 | 0.5 | | | | | | |
| | 3 | 430 | 439 | 2.1 | | | | | | |
| June 2, 2011 | 0 | 0 | -1 | - | 1.6 | 0.9821 | -0.238 | 1.0000 | 99.7% | Pass |
| | 1 | 78 | 77 | -1.3 | | | | | | |
| | 2 | 178 | 175 | -1.7 | | | | | | |
| | 3 | 416 | 408 | -1.9 | | | | | | |
| August 18, 2011 | 0 | 0 | -1 | - | 2.1 | 0.9774 | -0.274 | 1.0000 | 100.0% | Pass |
| | 1 | 58 | 57 | -1.7 | | | | | | |
| | 2 | 182 | 178 | -2.2 | | | | | | |
| | 3 | 419 | 409 | -2.4 | | | | | | |
| November 7, 2011 | 0 | 0 | 0 | - | 0.9 | 1.0017 | 0.477 | 1.0000 | 99.7% | Pass |
| | 1 | 50 | 51 | 2.0 | | | | | | |
| | 2 | 190 | 191 | 0.5 | | | | | | |
| | 3 | 387 | 388 | 0.3 | | | | | | |

¹Acceptance criteria:

1. Measured and audit point difference ≤ ±15%
2. Slope ≥ 0.9 and ≤ 1.10
3. R² ≥ 0.9950
4. Y-intercept ≤ ±3% of full scale
5. Converter efficiency ≥ 96.0%

Table 2-35: Performance Audit Summary – PM_{2.5}

| Period | External Leak Check Error (LPM) | Ambient Temperature Error (°C) | Ambient Pressure Error (mmHg) | Flow Rate | | Pass/Fail ¹ |
|------------------|---------------------------------|--------------------------------|-------------------------------|--------------------------------------|------------------------------------|------------------------|
| | | | | Flow Rate Accuracy Percent Error (%) | Design Flow Test Percent Error (%) | |
| March 16, 2011 | 0.1 | -0.3 | -2 | 0.6 | 0.2 | Pass |
| June 3, 2011 | 0.2 | -1.4 | -1 | 1.2 | -1.2 | Pass |
| August 18, 2011 | 0.4 | -0.3 | -1 | 0.0 | 0.0 | Pass |
| November 8, 2011 | 0.3 | 0.6 | -3 | -1.2 | 1.2 | Pass |

¹ Acceptance criteria:

1. Leak check $\leq \pm 1.0$ LPM
2. Temperature $\leq \pm 2.0$ °C
3. Pressure $\leq \pm 10$ mmHg
4. Flow rate error $\leq \pm 4\%$ audit standard
5. Design flow test $\leq \pm 5\%$ design flow rate

Table 2-36: Performance Audit Summary – PM₁₀

| Period | External Leak Check Error (LPM) | Ambient Temperature Error (°C) | Ambient Pressure Error (mmHg) | Flow Rate | | Pass/Fail ¹ |
|------------------|---------------------------------|--------------------------------|-------------------------------|--------------------------------------|------------------------------------|------------------------|
| | | | | Flow Rate Accuracy Percent Error (%) | Design Flow Test Percent Error (%) | |
| March 16, 2011 | 0.3 | -0.8 | -2 | 0.0 | 0.8 | Pass |
| June 3, 2011 | 0.2 | 0.0 | -2 | 0.0 | 0.0 | Pass |
| August 18, 2011 | 0.4 | -1.8 | -2 | 0.0 | 0.0 | Pass |
| November 8, 2011 | 0.0 | 0.7 | -4 | -0.6 | 0.6 | Pass |

¹ Acceptance criteria:

1. Leak check $\leq \pm 1.0$ LPM
2. Temperature $\leq \pm 2.0$ °C
3. Pressure $\leq \pm 10$ mmHg
4. Flow rate error $\leq \pm 4\%$ audit standard
5. Design flow test $\leq \pm 5\%$ design flow rate

Table 2-37: June 2, 2011 Meteorological Performance Audit Summary

| Parameter | Limit | Units | Max Error | Status |
|---|--------------------------------------|------------------|-----------|--------|
| Wind Speed Accuracy | $\leq \pm 0.20 + 5\%$ known input | m/s | 0.41 | Pass |
| Wind Speed Torque | ≤ 0.5 | m/s | 0.16 | Pass |
| Wind Direction Accuracy | $\leq \pm 5$ | Degree | 1 | Pass |
| Wind Direction Linearity | $\leq \pm 3$ | Degree | 2 | Pass |
| Wind Direction Torque | ≤ 0.5 | m/s | 0.39 | Pass |
| Vertical Wind Speed Accuracy | $\leq \pm 0.20 + 5\%$ known input | m/s | 0.39 | Pass |
| Vertical Wind Speed Torque | ≤ 0.25 | m/s | 0.20 | Pass |
| 2-m Temperature Accuracy | $\leq \pm 0.50$ | °C | 0.07 | Pass |
| 10-m Temperature Accuracy | $\leq \pm 0.50$ | °C | 0.10 | Pass |
| Air Temperature Difference | $\leq \pm 0.10$ | °C | 0.03 | Pass |
| Solar Radiation Accuracy ≤ 200 W/m ² | $\leq \pm 10$ | W/m ² | 2 | Pass |
| Solar Radiation Accuracy > 200 W/m ² | $\leq \pm 5$ | Mean % error | 1.5 | Pass |

Table 2-38: November 7, 2011 Meteorological Performance Audit Summary

| Parameter | Limit | Units | Max Error | Status |
|---|--------------------------------------|------------------|-----------|--------|
| Wind Speed Accuracy | $\leq \pm 0.20 + 5\%$ known input | m/s | 0.41 | Pass |
| Wind Speed Torque | ≤ 0.5 | m/s | 0.16 | Pass |
| Wind Direction Accuracy | $\leq \pm 5$ | Degree | 4 | Pass |
| Wind Direction Linearity | $\leq \pm 3$ | Degree | 2 | Pass |
| Wind Direction Torque | ≤ 0.5 | m/s | 0.32 | Pass |
| Vertical Wind Speed Accuracy | $\leq \pm 0.20 + 5\%$ known input | m/s | 0.32 | Pass |
| Vertical Wind Speed Torque | ≤ 0.25 | m/s | 0.24 | Pass |
| 2-m Temperature Accuracy | $\leq \pm 0.50$ | °C | 0.08 | Pass |
| 10-m Temperature Accuracy | $\leq \pm 0.50$ | °C | 0.11 | Pass |
| Air Temperature Difference | $\leq \pm 0.10$ | °C | 0.05 | Pass |
| Solar Radiation Accuracy ≤ 200 W/m ² | $\leq \pm 10$ | W/m ² | 6 | Pass |
| Solar Radiation Accuracy > 200 W/m ² | $\leq \pm 5$ | Mean % error | - | Pass |

Table 2-39: Wainwright PM_{2.5} PEP Audit Results

| Date | BAM 1020 Results (µg/m ³) | PEP Audit Results (µg/m ³) | Difference (µg/m ³) | Bias ¹ (µg/m ³) |
|------------|---------------------------------------|--|---------------------------------|--|
| 2-Oct-2011 | 3.2 | 1.02 | 2.18 | 1.74 |
| 3-Oct-2011 | 3.2 | 1.53 | 1.67 | |
| 4-Oct-2011 | 2.4 | 0.43 | 1.97 | |
| 5-Oct-2011 | 2.7 | 1.11 | 1.59 | |
| 6-Oct-2011 | 2.4 | 0.77 | 1.63 | |
| 7-Oct-2011 | 2.3 | 0.92 | 1.38 | |

¹ Average over the population of the absolute value of the individual pair concentration differences with a goal of ≤ 4 µg/m³ per quarter

3. MONITORING DATA NETWORK SUMMARY

3.1 AIR QUALITY DATA SUMMARY

Table 3-1 provides quarterly and annual averages of the criteria pollutant concentrations measured from January 1, 2011 through December 31, 2011 and compared to national and Alaska air quality standards (NAAQS/AAQS). The highest and second highest critical pollutant concentrations are also provided in Table 3-1 and compared to the respective primary and secondary air quality standards. Figures 3-1 through 3-9 provide plots of annual averages of the criteria pollutant concentrations at Nuiqsut station along with respective NAAQS/AAQS standards for comparison.

Table 3-1: Nuiqsut Ambient Air Monitoring Summary Data

| Pollutant | National and Alaska Ambient Air Quality Standards (NAAQS/AAAQS) | | Nuiqsut Ambient Air Monitoring – Pollutant Data | | | | | | |
|-------------------------------------|---|---------------------|---|-------------------------|-------------------------|-------------------------|-------------------------|--------|----------------------|
| | Concentration | Averaging Period | Averaging Period | 1 st Quarter | 2 nd Quarter | 3 rd Quarter | 4 th Quarter | Annual | YTD % of NAAQS/AAAQS |
| Carbon Monoxide (CO) | 35 ppm (40,000 µg/m ³) | 1-Hour ¹ | 1 st Highest, 1-Hour Average | 2 | 1 | 1 | 1 | 2 | 5.7% |
| | | | 2 nd Highest, 1-Hour Average | 1 | 1 | 1 | 1 | 1 | 2.9% |
| | 9 ppm (10,000 µg/m ³) | 8-Hour ¹ | 1 st Highest, 8-Hour Average | 1 | 1 | 1 | 1 | 1 | 11.1% |
| | | | 2 nd Highest, 8-Hour Average | 1 | 1 | 1 | 1 | 1 | 11.1% |
| Nitrogen Dioxide (NO ₂) | 100.0 ppb (190 µg/m ³) | 1-Hour ² | Daily Max 1-Hour Averages (98 th Percentile) | - | - | - | - | 20.9 | 20.9% |
| | | | 1 st Highest, 1-Hour Average | 27.0 | 13.4 | 13.8 | 46.5 | 46.5 | 46.5% |
| | | | 2 nd Highest, 1-Hour Average | 26.0 | 13.1 | 13.6 | 25.6 | 27.0 | 27.0% |
| | 53 ppb (100 µg/m ³) | Annual | Average of Period | 3 | 1 | 1 | 2 | 2 | 3.8% |
| Ozone (O ₃) | 0.075 ppm (150 µg/m ³) | 8-Hour ³ | 4 th Highest, 8-Hour Average | 0.050 | 0.052 | 0.031 | 0.038 | 0.052 | 69.3% |
| | | | 1 st Highest, 8-Hour Average | 0.051 | 0.053 | 0.032 | 0.038 | 0.053 | 70.7% |
| | | | 2 nd Highest, 8-Hour Average | 0.051 | 0.053 | 0.032 | 0.038 | 0.053 | 70.7% |

¹ Not to be exceeded more than once each year.

² To attain this standard, the 3-year average of the 98th percentile of the annual daily maximum 1-hour average must not exceed 100 ppb. This standard is only an NAAQS, not an AAAQS.

³ To attain this standard, the 3-year average of the annual fourth-highest daily maximum 8-hour average must not exceed 0.075 ppm.

Table 3-1 Continued: Nuiqsut Ambient Air Monitoring Summary Data

| Pollutant | National and Alaska Ambient Air Quality Standards (NAAQS/AAAQS) | | Nuiqsut Ambient Air Monitoring – Pollutant Data | | | | | | |
|-----------------------------------|---|----------------------|---|-------------------------|-------------------------|-------------------------|-------------------------|--------|----------------------|
| | Concentration | Averaging Period | Averaging Period | 1 st Quarter | 2 nd Quarter | 3 rd Quarter | 4 th Quarter | Annual | YTD % of NAAQS/AAAQS |
| Sulfur Dioxide (SO ₂) | 75.0 ppb (196 µg/m ³) | 1-Hour ¹ | Daily Max 1-Hour Averages (99 th Percentile) | - | - | - | - | 4.7 | 6.3% |
| | | | 1 st Highest, 1-Hour Average | 6.0 | 40.9 | 12.7 | 4.5 | 40.9 | 54.5% |
| | | | 2 nd Highest, 1-Hour Average | 5.0 | 4.5 | 6.0 | 2.6 | 12.7 | 16.9% |
| | 500.0 ppb (1,300 µg/m ³) | 3-Hour ² | 1st Highest, 3-Hour Average | 3.7 | 13.3 | 4.2 | 4.2 | 13.3 | 2.7% |
| | | | 2nd Highest, 3-Hour Average | 3.3 | 1.2 | 2.7 | 2.7 | 4.2 | 0.8% |
| | 140.0 ppb (365 µg/m ³) | 24-Hour ² | 1st Highest, 24-Hour Average | 3.0 | 1.2 | 1.1 | 0.8 | 3.0 | 2.1% |
| | | | 2nd Highest, 24-Hour Average | 2.5 | 0.1 | 0.3 | 0.8 | 2.5 | 1.9% |
| | 30.0 ppb (80 µg/m ³) | Annual | Average of Period | 0.3 | -0.4 | 0.1 | 0.2 | 0.0 | 0.0% |

¹ To attain this standard, the 3-year average of the 99th percentile of the annual daily maximum 1-hour average must not exceed 75.0 ppb.

² Not to be exceeded more than once each year.

Table 3-1 Continued: Nuiqsut Ambient Air Monitoring Summary Data

| Pollutant | National and Alaska Ambient Air Quality Standards (NAAQS/AAQS) | | Nuiqsut Ambient Air Monitoring – Pollutant Data | | | | | | |
|---|--|----------------------|---|-------------------------|-------------------------|-------------------------|-------------------------|-------------|-----------------------------|
| | Concentration | Averaging Period | Averaging Period | 1 st Quarter | 2 nd Quarter | 3 rd Quarter | 4 th Quarter | Annual | YTD % of NAAQS/AAQS |
| Particulate Matter <2.5 microns (PM _{2.5}) | 35.0 µg/m ³ | 24-Hour ¹ | 98 th Percentile, 24-Hour Average | - | - | - | - | 6.3 | 18.0% |
| | | | 1 st Highest, 24-Hour Average | 6.0 | 6.4 | 4.9 | 14.4 | 14.4 | 41.1% |
| | | | 2 nd Highest, 24-Hour Average | 5.6 | 6.3 | 4.6 | 10.1 | 10.1 | 28.9% |
| | 15.0 µg/m ³ | Annual ² | Average of Period | 1.9 | 1.9 | 0.4 | 1.4 | 1.4 | 9.3% |
| Particulate Matter <10 microns ¹ (PM ₁₀) | 150 µg/m ³ | 24-Hour ³ | 1 st Highest, 24-Hour Average | 10 | 220 ⁽⁴⁾ | 120 | 10 | 220 | 146.7%⁽⁴⁾ |
| | | | 2 nd Highest, 24-Hour Average | 10 | 40 | 40 | 10 | 120 | 80.0% |

¹ To attain this standard, the 3-year average of the 98th percentile of the 24-hour concentration must not exceed 35.0 µg/m³.

² To attain this standard, the 3-year average of the weighted annual mean PM_{2.5} concentration must not exceed 15.0 µg/m³.

³ Not to be exceeded more than once per year on average over three years.

⁴ The 1st highest reading of 220 µg/m³ is not an exceedance according to this standard. High PM₁₀ concentrations were measured on June 28, 2011 during a period of high winds from the east northeast direction. The average wind speeds were 10-12 m/s with wind directions between 53-77 degrees (clockwise from north) during the period of high PM₁₀ concentrations. These ENE winds were likely to have transported dust from the Colville River delta, since there was no snow cover at this time. Conditions were also quite dry at the time, as the nearby Deadhorse airport recorded only a trace of precipitation between June 16 and June 28, 2011.




Figure 3-1: 8-Hour Average O₃ and NAAQS/AAAQS Standard




Figure 3-2: 1-Hour Average SO₂ and NAAQS/AAAQS Standard




Figure 3-3: 3-Hour Average SO₂ and NAAQS/AAAQS Standard




Figure 3-4: 24-Hour Average SO₂ and NAAQS/AAAQS Standard




Figure 3-5: 1-Hour Average CO and NAAQS/AAAQS Standard




Figure 3-6: 8-Hour Average CO and NAAQS/AAAQS Standard




Figure 3-7: 1-Hour Average NO₂ and NAAQS Standard¹

¹No valid precision checks from February 17 to March 10, 2011 resulted in data invalidation and the gap seen in the graph.




Figure 3-8: 24-Hour Average PM_{2.5} and NAAQS/AAAQS Standard




Figure 3-9: 24-Hour Average PM₁₀ and NAAQS/AAQS Standard

3.2 METEOROLOGICAL DATA SUMMARY

3.2.1 WIND SPEED (WS) AND WIND DIRECTION (WD) CLIMATOLOGY

Table 3-2 provides the mean and maximum hourly wind speeds at the nearby Kuparuk meteorological station, located approximately 50 miles northeast of Nuiqsut. The summary in Table 3-2 is for comparison purposes and can be contrasted with Table 3-3, which is a statistical summary of horizontal and vertical wind speed measurements during the meteorological monitoring year at the Nuiqsut station.

Figure 3-10 provides an annual wind rose for the Nuiqsut station and Figure 3-11 provides quarterly wind roses. Winds were predominantly from the east-northeast with other minor wind components. Table 3-4 is the annual wind analysis table and Tables 3-5 to 3-8 are the quarterly wind analysis tables. Figure 3-12 provides the annual wind rose superimposed over a Nuiqsut area map, centered at the approximate location of the monitoring station.

Table 3-2: Average and Maximum Wind Speeds at Kuparuk

| Monitoring Period | Mean Hourly Average Wind Speed (m/s) | Maximum Hourly Average Wind Speed (m/s) |
|-------------------------|--------------------------------------|---|
| 1 st Quarter | 5.0 | 23.1 |
| 2 nd Quarter | 5.4 | 14.4 |
| 3 rd Quarter | 5.2 | 11.3 |
| 4 th Quarter | 4.6 | 14.9 |
| Monitoring Year | 5.1 | 23.1 |

Table 3-3: Average and Maximum Wind Speeds at Nuiqsut Station

| Monitoring Period | Mean Hourly Average Horizontal Wind Speed (m/s) | Mean Hourly Average Vertical Wind Speed (m/s) | Maximum Hourly Average Horizontal Wind Speed (m/s) | Maximum Hourly Average Vertical Wind Speed (m/s) |
|-------------------------|---|---|--|--|
| 1 st Quarter | 4.29 | 0.22 | 18.77 | 1.19 |
| 2 nd Quarter | 4.84 | 0.35 | 13.13 | 1.78 |
| 3 rd Quarter | 4.91 | 0.28 | 12.17 | 0.87 |
| 4 th Quarter | 4.39 | 0.25 | 16.76 | 1.23 |
| Monitoring Year | 4.62 | 0.28 | 18.77 | 1.78 |






Figure 3-10: Nuiqsut Annual Wind Rose


1st Quarter (1/1/11 – 3/31/11)




2nd Quarter (4/1/11 – 6/30/11)



3rd Quarter (7/1/11 – 9/30/11)



4th Quarter (10/1/11 – 12/31/11)



Wind Classes, m/s



Figure 3-11: Nuiqsut Quarterly Wind Roses

Table 3-4: Annual Wind Rose Frequency Distribution Percentage

| Frequency Distribution (Percent) | | | | | | |
|----------------------------------|--------------|--------------|--------------|-------------|-------------|--------------|
| Direction | Speed (m/s) | | | | | Total |
| | 0.5-2.8 | 2.8-5.5 | 5.5-8.3 | 8.3-11.0 | >11.0 | |
| N | 0.91 | 0.94 | 0.09 | 0.00 | 0.00 | 1.94 |
| NNE | 1.75 | 2.08 | 0.52 | 0.00 | 0.00 | 4.35 |
| NE | 2.34 | 5.27 | 3.55 | 1.35 | 0.29 | 12.80 |
| ENE | 3.43 | 7.57 | 8.02 | 3.87 | 1.20 | 24.09 |
| E | 2.48 | 4.76 | 3.19 | 1.30 | 0.44 | 12.17 |
| ESE | 1.66 | 1.03 | 0.35 | 0.06 | 0.00 | 3.10 |
| SE | 0.83 | 0.43 | 0.04 | 0.00 | 0.00 | 1.30 |
| SSE | 0.93 | 0.22 | 0.00 | 0.00 | 0.00 | 1.15 |
| S | 1.70 | 1.17 | 0.27 | 0.02 | 0.01 | 3.17 |
| SSW | 3.41 | 4.73 | 0.82 | 0.06 | 0.07 | 9.09 |
| SW | 2.90 | 2.96 | 1.24 | 0.06 | 0.02 | 7.18 |
| WSW | 1.62 | 2.30 | 1.73 | 0.95 | 0.24 | 6.84 |
| W | 1.44 | 1.55 | 0.90 | 0.50 | 0.45 | 4.84 |
| WNW | 1.44 | 1.07 | 0.38 | 0.06 | 0.02 | 2.97 |
| NW | 0.99 | 1.12 | 0.12 | 0.06 | 0.00 | 2.29 |
| NNW | 0.89 | 0.72 | 0.06 | 0.00 | 0.00 | 1.67 |
| Summary | 28.72 | 37.92 | 21.28 | 8.29 | 2.74 | 98.95 |

Table 3-5: First Quarter Wind Rose Frequency Distribution Percentage

| Frequency Distribution (Percent) | | | | | | |
|----------------------------------|--------------|--------------|--------------|-------------|-------------|--------------|
| Direction | Speed (m/s) | | | | | Total |
| | 0.5-2.8 | 2.8-5.5 | 5.5-8.3 | 8.3-11.0 | >11.0 | |
| N | 0.46 | 0.05 | 0.00 | 0.00 | 0.00 | 0.51 |
| NNE | 1.13 | 0.10 | 0.00 | 0.00 | 0.00 | 1.23 |
| NE | 3.29 | 0.82 | 0.21 | 0.05 | 0.00 | 4.37 |
| ENE | 6.21 | 3.23 | 0.72 | 0.15 | 0.31 | 10.62 |
| E | 3.95 | 4.00 | 1.80 | 1.08 | 1.39 | 12.22 |
| ESE | 1.90 | 1.13 | 0.26 | 0.15 | 0.00 | 3.44 |
| SE | 1.33 | 0.51 | 0.15 | 0.00 | 0.00 | 1.99 |
| SSE | 1.08 | 0.21 | 0.00 | 0.00 | 0.00 | 1.29 |
| S | 1.59 | 2.67 | 1.08 | 0.10 | 0.05 | 5.49 |
| SSW | 2.57 | 12.58 | 2.41 | 0.26 | 0.31 | 18.13 |
| SW | 3.85 | 5.34 | 2.36 | 0.26 | 0.10 | 11.91 |
| WSW | 1.49 | 3.80 | 4.52 | 3.03 | 0.77 | 13.61 |
| W | 1.85 | 2.10 | 1.95 | 1.08 | 1.33 | 8.31 |
| WNW | 0.62 | 1.23 | 0.26 | 0.00 | 0.00 | 2.11 |
| NW | 0.31 | 0.67 | 0.05 | 0.00 | 0.00 | 1.03 |
| NNW | 0.10 | 0.15 | 0.00 | 0.00 | 0.00 | 0.25 |
| Summary | 31.73 | 38.59 | 15.77 | 6.16 | 4.26 | 96.51 |

Table 3-6: Second Quarter Wind Rose Frequency Distribution Percentage

| Frequency Distribution (Percent) | | | | | | |
|----------------------------------|--------------|--------------|--------------|-------------|-------------|---------------|
| Direction | Speed (m/s) | | | | | Total |
| | 0.5-2.8 | 2.8-5.5 | 5.5-8.3 | 8.3-11.0 | >11.0 | |
| N | 1.12 | 1.75 | 0.00 | 0.00 | 0.00 | 2.87 |
| NNE | 1.41 | 3.35 | 0.68 | 0.00 | 0.00 | 5.44 |
| NE | 2.09 | 8.16 | 3.45 | 0.49 | 0.00 | 14.19 |
| ENE | 3.30 | 7.82 | 13.61 | 7.09 | 1.51 | 33.33 |
| E | 2.96 | 6.07 | 3.94 | 0.92 | 0.00 | 13.89 |
| ESE | 2.38 | 1.31 | 0.29 | 0.00 | 0.00 | 3.98 |
| SE | 0.34 | 0.19 | 0.00 | 0.00 | 0.00 | 0.53 |
| SSE | 0.39 | 0.19 | 0.00 | 0.00 | 0.00 | 0.58 |
| S | 0.24 | 0.44 | 0.05 | 0.00 | 0.00 | 0.73 |
| SSW | 1.07 | 1.80 | 0.15 | 0.00 | 0.00 | 3.02 |
| SW | 0.97 | 2.96 | 1.02 | 0.00 | 0.00 | 4.95 |
| WSW | 0.68 | 2.14 | 0.44 | 0.10 | 0.00 | 3.36 |
| W | 1.17 | 0.92 | 0.44 | 0.29 | 0.34 | 3.16 |
| WNW | 2.14 | 0.92 | 0.63 | 0.15 | 0.10 | 3.94 |
| NW | 1.36 | 1.60 | 0.15 | 0.10 | 0.00 | 3.21 |
| NNW | 1.41 | 1.26 | 0.00 | 0.00 | 0.00 | 2.67 |
| Summary | 23.03 | 40.88 | 24.85 | 9.14 | 1.95 | 100.00 |

Table 3-7: Third Quarter Wind Rose Frequency Distribution Percentage

| Frequency Distribution (Percent) | | | | | | |
|----------------------------------|--------------|--------------|--------------|-------------|-------------|---------------|
| Direction | Speed (m/s) | | | | | Total |
| | 0.5-2.8 | 2.8-5.5 | 5.5-8.3 | 8.3-11.0 | >11.0 | |
| N | 0.88 | 1.16 | 0.32 | 0.00 | 0.00 | 2.36 |
| NNE | 1.44 | 3.15 | 0.65 | 0.00 | 0.00 | 5.24 |
| NE | 1.76 | 7.92 | 7.50 | 2.27 | 0.37 | 19.82 |
| ENE | 1.76 | 14.03 | 13.25 | 4.26 | 0.69 | 33.99 |
| E | 1.07 | 5.88 | 4.03 | 0.42 | 0.00 | 11.40 |
| ESE | 1.39 | 1.07 | 0.19 | 0.09 | 0.00 | 2.74 |
| SE | 0.60 | 0.93 | 0.00 | 0.00 | 0.00 | 1.53 |
| SSE | 0.69 | 0.46 | 0.00 | 0.00 | 0.00 | 1.15 |
| S | 0.97 | 0.37 | 0.00 | 0.00 | 0.00 | 1.34 |
| SSW | 1.39 | 1.44 | 0.14 | 0.00 | 0.00 | 2.97 |
| SW | 1.16 | 1.34 | 0.65 | 0.00 | 0.00 | 3.15 |
| WSW | 0.97 | 1.76 | 0.42 | 0.05 | 0.00 | 3.20 |
| W | 1.48 | 1.76 | 0.28 | 0.00 | 0.00 | 3.52 |
| WNW | 1.39 | 1.16 | 0.32 | 0.09 | 0.00 | 2.96 |
| NW | 1.34 | 1.25 | 0.05 | 0.00 | 0.00 | 2.64 |
| NNW | 1.16 | 0.79 | 0.05 | 0.00 | 0.00 | 2.00 |
| Summary | 19.45 | 44.47 | 27.85 | 7.18 | 1.06 | 100.00 |

Table 3-8: Fourth Quarter Wind Rose Frequency Distribution Percentage

| Frequency Distribution (Percent) | | | | | | |
|----------------------------------|--------------|--------------|--------------|--------------|-------------|--------------|
| Direction | Speed (m/s) | | | | | Total |
| | 0.5-2.8 | 2.8-5.5 | 5.5-8.3 | 8.3-11.0 | >11.0 | |
| N | 1.17 | 0.73 | 0.00 | 0.00 | 0.00 | 1.90 |
| NNE | 3.02 | 1.56 | 0.73 | 0.00 | 0.00 | 5.31 |
| NE | 2.29 | 3.80 | 2.68 | 2.49 | 0.78 | 12.04 |
| ENE | 2.68 | 4.63 | 3.85 | 3.75 | 2.29 | 17.20 |
| E | 2.10 | 2.97 | 2.88 | 2.83 | 0.44 | 11.22 |
| ESE | 0.98 | 0.63 | 0.68 | 0.00 | 0.00 | 2.29 |
| SE | 1.07 | 0.05 | 0.00 | 0.00 | 0.00 | 1.12 |
| SSE | 1.56 | 0.00 | 0.00 | 0.00 | 0.00 | 1.56 |
| S | 4.05 | 1.32 | 0.00 | 0.00 | 0.00 | 5.37 |
| SSW | 8.68 | 3.71 | 0.68 | 0.00 | 0.00 | 13.07 |
| SW | 5.75 | 2.39 | 1.02 | 0.00 | 0.00 | 9.16 |
| WSW | 3.36 | 1.61 | 1.76 | 0.78 | 0.24 | 7.75 |
| W | 1.27 | 1.41 | 1.02 | 0.68 | 0.20 | 4.58 |
| WNW | 1.56 | 0.98 | 0.29 | 0.00 | 0.00 | 2.83 |
| NW | 0.88 | 0.93 | 0.24 | 0.15 | 0.00 | 2.20 |
| NNW | 0.83 | 0.63 | 0.20 | 0.00 | 0.00 | 1.66 |
| Summary | 41.25 | 27.35 | 16.03 | 10.68 | 3.95 | 99.26 |




Figure 3-12: Annual Wind Rose Superimposed on Site Map

3.2.2 TEMPERATURE CLIMATOLOGY

Tables 3-9 and 3-10 give the maximum and minimum daily mean temperatures, monthly mean temperatures, and maximum and minimum hourly average temperatures for the 2-meter and 10-meter temperature measurements, respectively. Figure 3-13 provides a graph of the 2-meter and 10-meter hourly average temperatures as well as hourly average temperatures at the nearby Kuparuk station. Figure 3-13 shows a plot of vertical temperature difference (the difference between 10-meter and 2-meter temperature values) during the monitoring year.

Table 3-9: 2-Meter Temperature Summary

| Period | Maximum Daily Mean Temperature (°C) | Minimum Daily Mean Temperature (°C) | Mean Temperature (°C) | Maximum Temperature (°C) | Minimum Temperature (°C) |
|-------------------------------|-------------------------------------|-------------------------------------|-----------------------|--------------------------|--------------------------|
| January 2011 | -3.2 | -43.6 | -25.7 | 0.2 | -46.3 |
| February 2011 | -2.0 | -33.4 | -21.9 | -0.5 | -36.5 |
| March 2011 | NA ¹ | NA ¹ | NA ¹ | NA ¹ | NA ¹ |
| 1st Quarter | -2.0 | -43.6 | -24.0 | 0.2 | -46.3 |
| April 2011 | NA ¹ | NA ¹ | NA ¹ | NA ¹ | NA ¹ |
| May 2011 | NA ¹ | NA ¹ | NA ¹ | NA ¹ | NA ¹ |
| June 2011 | 13.7 | -1.0 | 4.5 | 21.3 | -3.7 |
| 2nd Quarter | 13.7 | -1.0 | 4.5 | 21.3 | -3.7 |
| July 2011 | 15.7 | 4.0 | 9.8 | 20.4 | 0.9 |
| August 2011 | 14.4 | 3.1 | 7.4 | 18.3 | -1.4 |
| September 2011 | 9.0 | -2.7 | 2.5 | 14.3 | -6.1 |
| 3rd Quarter | 15.7 | -2.7 | 6.6 | 20.4 | -6.1 |
| October 2011 | -0.6 | -17.1 | -5.3 | 0.2 | -21.1 |
| November 2011 | -5.4 | -37.5 | -22.3 | -3.5 | -39.3 |
| December 2011 | -10.3 | -35.9 | -26.8 | -6.7 | -39.6 |
| 4th Quarter | -0.6 | -37.5 | -18.1 | 0.2 | -39.6 |
| Monitoring Year | 15.7 | -43.6 | -8.6 | 21.3 | -46.3 |

¹No data due to aspirator failure on the two meter temperature sensor.

Table 3-10: 10-Meter Temperature Summary

| Period | Maximum Daily Mean Temperature (°C) | Minimum Daily Mean Temperature (°C) | Mean Temperature (°C) | Maximum Temperature (°C) | Minimum Temperature (°C) |
|-------------------------------|-------------------------------------|-------------------------------------|-----------------------|--------------------------|--------------------------|
| January 2011 | -3.0 | -43.1 | -25.4 | 0.4 | -46.5 |
| February 2011 | -1.9 | -33.4 | -21.8 | -0.5 | -36.7 |
| March 2011 | -13.4 | -32.5 | -22.7 | -9.9 | -35.7 |
| 1st Quarter | -1.9 | -43.1 | -23.3 | 0.4 | -46.5 |
| April 2011 | -7.0 | -27.0 | -19.9 | -4.1 | -31.9 |
| May 2011 | 3.2 | -15.7 | -6.0 | 7.3 | -20.5 |
| June 2011 | 13.2 | -1.5 | 4.0 | 20.3 | -3.9 |
| 2nd Quarter | 13.2 | -27.0 | -7.5 | 20.3 | -31.9 |
| July 2011 | 15.5 | 3.7 | 9.5 | 19.8 | 0.8 |
| August 2011 | 14.3 | 2.8 | 7.2 | 17.5 | -1.4 |
| September 2011 | 9.2 | -2.7 | 2.5 | 13.7 | -5.6 |
| 3rd Quarter | 15.5 | -2.7 | 6.4 | 19.8 | -5.6 |
| October 2011 | -0.6 | -16.1 | -5.1 | 0.1 | -20.9 |
| November 2011 | -5.3 | -37.7 | -22.1 | -3.6 | -39.5 |
| December 2011 | -10.2 | -35.7 | -26.6 | -6.3 | -39.3 |
| 4th Quarter | -0.6 | -37.7 | -17.9 | 0.1 | -39.5 |
| Monitoring Year | 15.5 | -43.1 | -10.6 | 20.3 | -46.5 |




Figure 3-13: Hourly Average 2-Meter and 10-Meter Temperatures




Figure 3-14: Hourly Average Vertical Temperature Difference¹

¹Aspirator malfunction on the two meter temperature sensor from February 27 to June 1, 2011 resulted in invalid data and the gap seen in the graph.

3.2.3 OTHER METEOROLOGICAL PARAMETERS

The other meteorological parameter measured at the Nuiqsut station is solar radiation. Table 3-11 provides a summary of this parameter for the 2011 monitoring year. Figure 3-15 is a plot of annual hourly average solar radiation. The solar radiation data are available in monthly tabular format in Appendix D.

Table 3-11: Solar Radiation Summary

| Period | Mean Solar Radiation (W/m ²) | Maximum Solar Radiation (W/m ²) |
|-------------------------------|--|---|
| January 2011 | 1 | 24 |
| February 2011 | 19 | 258 |
| March 2011 | 94 | 535 |
| 1st Quarter | 39 | 535 |
| April 2011 | 206 | 722 |
| May 2011 | 257 | 724 |
| June 2011 | 257 | 727 |
| 2nd Quarter | 240 | 727 |
| July 2011 | 203 | 697 |
| August 2011 | 141 | 617 |
| September 2011 | 49 | 438 |
| 3rd Quarter | 132 | 697 |
| October 2011 | 23 | 314 |
| November 2011 | 3 | 63 |
| December 2011 | 0 | 2 |
| 4th Quarter | 9 | 314 |
| Monitoring Year | 105 | 727 |




Figure 3-15: Hourly Average Solar Radiation

4. REFERENCES

- U.S. Environmental Protection Agency (EPA), *On-Site Meteorological Program Guidance for Regulatory Modeling Applications*, Office of Air Quality Planning and Standards, Research Triangle Park, North Carolina, EPA-450/4-87-013, Revised August 1995.
- EPA, *Ambient Monitoring Guidelines for Prevention of Significant Deterioration (PSD)*. Office of Air Quality Planning and Standards, Research Triangle Park, North Carolina, EPA-450/4-87-007, 1987.
- EPA, *Meteorological Monitoring Guidance for Regulatory Modeling Applications*, Office of Air Quality Planning and Standards, Research Triangle Park, North Carolina, EPA-454/R-99-005, 2000.
- U.S. Department of Commerce, National Climatic Data Center, Asheville, North Carolina, <http://www.ncdc.noaa.gov>.
- Western Regional Climate Center, Desert Research Institute, Reno Nevada, <http://www.wrcc.dri.edu/summary/climsmak.html>.
- Yamartino, R.J., *A Comparison of Several "Single-Pass" Estimators of the Standard Deviation of Wind Direction*, J. Climate Appl. Meteor., Vol. 23, pp. 1362-1366, 1984.